





FIRE FLOW REQUIREMENTS = 2000 GPM

EX HYDRANT - #10667
SEE FLOW TEST RESULTS THIS SHEET



**PERKINS
&
ORRISON**

FN INEFF ▲ E. ANNET ▲ FN JEFF

317 BROOK PARK PL., FOREST, VIRGINIA 24551
PHONE: 540-525-5985 FAX: 540-525-5986
EMAIL: pro@perkins-orrison.com

17 W. NELSON STREET LEXINGTON, VIRGINIA 24450
PHONE: 540-464-9001 FAX: 540-464-5009
EMAIL: pro@perkins-orrison.com

CONSULTANTS

City of Roanoke Planning, Building, & Development
COMPREHENSIVE DEVELOPMENT PLAN
<u>APPROVED</u>
by Aaron Cypher 10/17/2022

SEAL:



JOB:

950 ORANGE AVE
CAR WASH
CITY OF ROANOKE, VIRGINIA

CLIENT: THOMAS BUILDERS

2	10/06/2022	PER CITY COMMENTS
1	09/23/2022	PER CITY COMMENTS
MARK	DATE	DESCRIPTION
ISSUE:		07/07/2022
CONTOUR INTERVAL:		2
DESIGNED BY:		RH
DRAWN BY:		PW
CHECKED BY:		RH

SHEET TITLE

WATER SYSTEM EXHIBIT



SHEET	JURISDICTION PROJECT #
C202A	CP22-0025
JOB NO.	SHEET NO
21436	6A