



PHONES:
OFFICE 344-1657
FAX 344-0285

VIRGINIA CONSTRUCTION
REGISTRATION NO. 20183

P. O. BOX 12961 ----- ROANOKE, VIRGINIA 24030

Test Location Aspen Grove

Date of Test 8-02-02

Name of Testing Firm Jack St. Clair & City of Roanoke

Person Observing Test Winston Carbett

Breif Description of Test(s) Hypostatic water pressure
test of 150lbs on 8" DI water main w/ 3/4" water services.

	Depth	Start Pressure	End Pressure	Start Time	End Time
Manhole #					
Manhole #					
Manhole #					
Manhole #					
Manhole #					
Manhole #					

Line From	Line Size	Line Length	Start Pressure	End Pressure	Mandrell
Mh ___ to Mh ___	<u>8"</u>	<u>530'</u>	<u>150lbs</u>	<u>150lbs</u>	<u>2 hrs. we</u>
Mh ___ to Mh ___					
Mh ___ to Mh ___					
Mh ___ to Mh ___					
Mh ___ to Mh ___					
Mh ___ to Mh ___					

Test Representative

Job Superintendent
Brian Hamilton