





100

WATER NOTES:

1. ALL MATERIALS AND CONSTRUCTION SHALL MEET ALL REQUIREMENTS OF THE ROANOKE COUNTY WATER SEWER REGULATIONS, 3rd EDITION.
2. MINIMIZE ANY DISTURBANCE TO EXISTING UTILITY SERVICES DURING CONSTRUCTION.
3. PROVIDE 3.0 FEET MINIMUM COVER.
4. ALL TAPS TO EXISTING WATER LINES OR STRUCTURES TO BE PERFORMED BY THE ROANOKE COUNTY UTILITY DEPARTMENT. ALL CONNECTION TO WATER LINES WILL BE COORDINATED AT THE PRE-CONSTRUCTION MEETING.
5. CURB STOP AND 8"x1" SADDLE TO BE PER REQUIREMENTS OF THE ROANOKE COUNTY WATER SEWER REGULATIONS, 3rd EDITION.



JOB NO.
R0300146.00

