




- NOTES:
- LOCATION OF ALL UTILITIES SHALL BE ASCERTAINED IN FIELD PRIOR TO CONSTRUCTION
 - EXIST. 6" & 8" WATER MAINS IN BERKLEY AVE. SHALL BE ABANDONED AFTER ALL SERVICES ARE TIED OVER TO NEW 8" WATER MAIN
 - (TYPICAL FOR ALL EXIST. VALVES TO BE ABANDONED):
REMOVE FRAME & COVER
FILL VALVE BOX WITH 0 FLOWABLE FILL

C:\Backup-work\K Drive\K-drive-081604\Logs\VVVA Logo\VVVA_Side_Logo_Color.gif

ENGINEERING SERVICES
2012 S. JEFFERSON STREET
SUITE 100
ROANOKE, VIRGINIA 24014
PHONE: (540) 853-5468
FAX: (540) 853-1017

REV.	DATE:	DESCRIPTION
	6/14/05	Press. Test to Dudding + 6" on mtn View 8" Dog Leg 195psi (Passed)
	7/13/05	Press. Test from Dudding to Chesterfield 195psi (Passed)

Drawn By: NHP
Designed By: LET
Checked By: JGR
Date: 10/12/2004
Scale: 1" = 50'



BERKLEY AVENUE, SW BURKS ST. TO CHESTERFIELD ST. WATERLINE REPLACEMENT

TAX MAP#: 143, 151, 152
CAD MAP#: 0631

PATH: C:\Land Projects 2004\CIP\BerkleyAveBurksSttoChesterfieldStSW.dwg

SHEET
2 of 2

PLAN NO.

1000