

PLUMBING FIXTURE SCHEDULE				
NOTES: 1. PROVIDE ALL HARDWARE AND APPURTENANCES FOR COMPLETE PLUMBING FIXTURE/EQUIPMENT INSTALLATION PER MANUFACTURER'S REQUIREMENTS. 2. COORDINATE ALL ELECTRICAL REQUIREMENTS WITH ELECTRICAL CONTRACTOR. 3. THE CONTRACTOR IS RESPONSIBLE TO PROVIDE ALL EQUIPMENT SHOWN IN THE PLUMBING SCHEDULES, PLUMBING PLANS, AND DETAILS. 4. ALL VALVES, HAMMER ARRESTORS, TPV SHALL BE ACCESSIBLE, COORDINATE ACCESS DOOR WITH ARCHITECTS. 5. PROVIDE WILKINS MODEL 40XL IN LINE CHECK VALVE ON CW AND HW SUPPLY LINES FOR MB-1 MOP BASIN. 6. COORDINATE PLUMBING FIXTURE LOCATIONS WITH ARCHITECTURAL DRAWINGS. REFER TO ARCHITECTURAL DRAWINGS FOR ADA FIXTURES HEIGHT AND CLEARANCES. 7. REFER TO SUPERVISED PLAY ELEVATIONS ON DRAWING A401 FOR WC-3 INSTALLATION TO ACCOMMODATE ADA REQUIREMENTS.				
MARK	DESCRIPTION	MANUFACTURER	MODEL	COMMENTS
BF-1	BOTTLE FILLER	MOEN	"SIP" #S5510 FAUCET	TRADITIONAL BEVERAGE FAUCET, ADA, METAL CONSTRUCTION, LEVER STYLE HANDLE, DECK MOUNT, DESIGNED TO INSTALL THROUGH 1 HOLE. FLOW SHALL BE LIMITED TO 1.5 GPM, NSF 61/9 CERTIFIED. INSTALL AT THE LEFT SIDE OF SINK FAUCET. QUARTER-TURN 3/8" CHROME PLATED HEAVY BRASS ANGLE SUPPLY AND LOOSE KEY STOP WITH CHROME PLATED SOFT, COPPER RISER. PROVIDE RESTRICTIVE DEVICE AND ESCUTCHEON PLATE. PROVIDED 5 YEAR WARRANTY AGAINST LEAKS, DRIPS, AND FINISH.
EE-1/MV-1	SWING-AWAY EYEWASH/MIXING VALVE	BRADLEY	#S19-270B WITH S19-2000EFXB-R-SE MIXING VALVE WITH TAMPERPROOF CABINET FOR MIXING VALVE	EMERGENCY, SWING-AWAY, DECK MOUNTED ADJACENT TO SINK TWIN CHROME PLATED SPRAY HEADS WITH CAPS AND RETAINING CHAIN/STRAPS MOUNTED ON BRASS SUPPLY ARMS, MINIMUM FLOW RATE OF 0.4 GPM AT 30 PSI (15 MIN.), INTEGRAL FLOW CONTROL, FITTING, CHROME-PLATED BRASS STAY-OPEN BALL VALVE HAND OPERATED BY LARGE HIGHLY VISIBLE STAINLESS STEEL PUSH HANDLE. BRADLEY NAVIGATOR #S19-2000EFXB-R-SE EMERGENCY THERMOSTATIC MIXING VALVE, ROUGH-BRASS WITH SURFACE MOUNT WHITE ENAMEL CABINET. INSTALL EYEWASH TO THE RIGHT SIDE OF THE SINK, THE HOLE THROUGH COUNTERTOP FOR THE EYEWASH SHALL BE 2-1/4" FROM THE RIGHT EDGE OF SINK CUTOUT AND 8-1/2" BACK FROM THE FRONT OF THE SINK CUTOUT.
EW-1	BOTTLE FILLER STATION WITH BI-LEVEL COOLER	ELKAY	BOTTLE FILLER STATION #EZH20 COOLER: LZSTL8WSLP CANE APRON: LKAPREZL	ADA, ELECTRIC WATER COOLER WITH CANE APRON (MODEL LKAPREZL) INSTALLED UNDER UPPER UNIT, REFRIGERATED, FILTERED, WALL HUNG, BI-LEVEL, LIGHT GRAY GRANITE FINISH, NON-SPLASH BASIN. STREAM PROJECTORS WITH PROTECTIVE HOODS, EASY-TOUCH FRONT AND SIDE PUSHBAR CONTROLS, WATERSENTRY PLUS FILTRATION SYSTEM, AUTOMATIC FILTER STATUS RESET WITH EACH FILTER CHANGE, 115/60/1, 5 FULL LOAD AMPS, 8 GPH CAPACITY BASED ON 80 DEG F INLET WATER, 90 DEG F AMBIENT AIR TEMP FOR 50 DEG F CHILLED DRINKING WATER. PVC 1/2" TRAP, FLOOR MOUNTED CARRIER. BOTTLE FILLER STATION, QUICK FILL RATE 1.1 GPM, UNIT MOUNTED, SS CONSTRUCTION, INTEGRAL DRAIN, SENSOR OPERATED WITH AUTOMATIC SHUT-OFF, REPLACEABLE WATER FILTER BOTTLE COUNTER, FILTER REPLACEMENT INDICATOR. ORIFICE SHALL BE OF 3/6" (MAXIMUM) AFF ON LOWER UNIT, 40" AFF ON UPPER UNIT, BOTTOM OF APRON SHALL BE 27" AFF. REFER TO ARCH. DRAWINGS FOR ADA INSTALLATION DETAILS.
FCO	FLOOR CLEANOUT	ZURN	#ZN-1400-BP-KC-SG	ADJUSTABLE FLOOR CLEANOUT, CAST IRON BODY, GAS AND WATER-TIGHT BRONZE PLUG, ROUND SCORIATED SECURED NICKEL-BRONZE TOP, ANCHOR FLANGE WITH CLAMP COLLAR, SOLID GASKETED COVER, NO-HUB OUTLET
FD-1	FLOOR DRAIN	ZURN	#ZN415-3NH-SS-Y	CAST IRON BODY, TYPE-S (5"x5") NICKEL BRONZE ADJUSTABLE SQUARE TOP, 3" BOTTOM OUTLET, FLUSHING COLLAR, ADJUSTABLE 1" TRAP, TRAP PRIMER CONNECTION FITTING, SEDIMENT BUCKET.
FD-3	FLOOR DRAIN	ZURN	#ZN-415-4NH-7LY-P	CAST IRON, SEDIMENT BUCKET, MEMBRANE CLAMP, ADJUSTABLE COLLAR, TYPE I POLISHED NICKEL BRONZE STRAINER WITH RAISED FLANGE, BOTTOM OUTLET. ADJUSTABLE 1" TRAP, TRAP PRIMER CONNECTION FITTING, SEDIMENT BUCKET.
GCO	GRADE CLEANOUT	ZURN	#ZN-1474-N	GRADE CLEANOUT, HEAVY DUTY HOUSING, POLISHED NICKEL BRONZE TOP, AND ZURN #Z1440 INTERNAL CLEANOUT AND BRONZE PLUG, TWO-WAY
HB-1	WALL HYDRANT	WOODFORD	#65	FREEZELESS, AUTOMATIC DRAINING, VACUUM BREAKER, 3/4" MALE HOSE THREADED CONNECTION, BRASS VALVE BODY AND SEAT, NON-FERROUS METAL STEM, STANDARD FINISH, WALL CLAMP, FURNISH TWO KEY OPERATORS. ASSE 1019 APPROVED AND LISTED. MOUNT AT 18" AFG UNLESS NOTED OTHERWISE ON DRAWING. PROVIDE MINIMUM 2 KEYS.
LAV-2/MV-3	LAVATORY	AMERICAN STANDARD	LAVATORY: AM STD. LUCERNE #0356-421 FAUCET: SLOAN OPTIMA PLUS #EBF-615-4-BDT AERATOR: SLOAN #EAF-63 (CODE 0335036), 0.5GPM, FIELD INSTALLED	ACCESSIBLE, ADA, WHITE, VITREOUS CHINA, 4" HIGH CONTOURED BACKSPASH, 20"x18" SIZE, SINGLE FAUCET HOLE, QUARTER-TURN 3/8" CHROME PLATED RISERS, 1-1/4" 17 GAUGE CAST BRASS 1/2" TRAP WITH CLEAN-OUT. PROVIDE 29" MINIMUM CLEARANCE FROM FLOOR TO BOTTOM OF APRON, TOP OF BASIN TO BE MAXIMUM OF 34" A.F.F. IN COMPLIANCE WITH ADA. PROVIDE PERFORATED DRAIN GRATE, OFFSET DRAIN, TAILPIECE AND SUPPLIES WITH STOPS. TRUEBRO HANDI LAV-GUARD PRE-MANUFACTURED P-TRAP, STOP VALVE AND SUPPLY LINE INSULATION KIT OR APPROVED EQUIVALENT BY BROCAR, MCGUIRE, PROFLO, PLUMBEREX. FAUCET- SENSOR ACTIVATED, BATTERY POWERED, BRASS CONSTRUCTION, CHROME-PLATED FINISH, CONVENTIONAL SPOUT WITH VANDAL-RESISTANT AERATOR, SINGLE HOLE INSTALLATION, FILTERED SOLENOID VALVE WITH SERVICEABLE STRAINER FILTER, TRIM PLATE KIT. MV-3-LEONARD ECO-MIX MODEL 270-LF-CP MIXING VALVE (ASSE 1070) CHROME PLATED FINISH OR APPROVED EQUIVALENT BY BRADLEY, LAWLOR, POWER. MOUNT CONTROLS AND BATTERIES IN WATERPROOF VANDAL-RESISTANT ENCLOSURE BELOW LAVATORY.
MB-1	MOP BASIN	MUSTEE	MOP SINK: #63M FAUCET: CHICAGO #897 AT 36" AFF	MOP SINK: 24" X 24" X 10" DEEP, FLOOR MOUNTED, MOLDED-STONE SMC ONE PIECE HOMOGENEOUS PRODUCT, AND INTEGRAL DRAIN WITH S.S. DOME STRAINER AND 3" OUTLET. FAUCET: TWO HANDLE EXPOSED MIXING FAUCET, SINGLE WING HANDLES, POLISHED CHROME PLATED, 3/4" HOSE, THREADED SPOUT WITH INTEGRAL VACUUM BREAKER, WALL BRACE, PAIL HOOK, INTEGRAL STOPS. PROVIDE FIAT #889-CC HANGER, #832-AA HOSE SHALL NOT BE LONGER THAN RIM OF MOP SINK.
SK-1/MV-3	SINK	ELKAY	SINK: ELKAY "LUSTERTONE" #DLR2022210 FAUCET: SLOAN #SF-2150 AERATOR: SLOAN #EAF-22 (CODE 0335021), 1.5 GPM, FIELD INSTALLED	SINK-SINGLE COMPARTMENT, TOP MOUNT, FAUCET DECK, SINGLE HOLE, 18 GAUGE, 304 STAINLESS STEEL, 16x16x10"(D) BOWL SIZE, COMPLETELY UNDERCOATED, 3-1/2" DIAMETER DRAIN OUTLET, REMOVABLE STAINLESS STEEL BASKET STRAINER AND NEOPRENE STOPPER, CHROME PLATED CAST BRASS 1/2" TRAP WITH CLEANOUT, 1-1/2" 17 GAUGE CHROME PLATED BRASS TAILPIECE, QUARTER-TURN 3/8" CHROME PLATED HEAVY BRASS ANGLE SUPPLIES AND LOOSE KEY STOPS WITH CHROME PLATED SOFT COPPER RISERS. FAUCET- SENSOR OPERATED, BATTERY POWERED, CHROME PLATED, BRASS CONSTRUCTION. PROVIDE FIELD INSTALLED AERATOR INSERT, ADJUSTABLE SENSOR EYE AND UNDERCOUNTER SOLID BRASS MV-3 MIXING VALVE (ASSE 1070), (MIXING VALVE SHALL NOT BE WYE PATTERN STYLE), ADJUSTABLE TEMPERATURE LIMIT STOP AND INTEGRAL CHECK VALVES. SET TEMPERATURE AT 110°F, WATERPROOF CONNECTORS AND CABLE. MOUNT CONTROLS AND BATTERIES IN WATERPROOF VANDAL-RESISTANT ENCLOSURE BELOW SINK, MAXIMUM FLOW TO BE 1.5 GPM. MV-3: LEONARD ECO-MIX MODEL 270-LF-CP MIXING VALVE (ASSE 1070) OR APPROVED EQUIVALENT BY BRADLEY, LAWLOR, POWER. PROVIDE RESTRICTIVE DEVICE.
SK-2/GD-1	SINK/GARBAGE DISPOSER	ELKAY	SINK: ELKAY "LUSTERTONE" #LRAD252160 FAUCET: DELTA B4410LF GARBAGE DISPOSER: ISE #BADGER 1, 115/60/1, 1/3 HP	SINK: ACCESSIBLE, ADA, SINGLE BOWL, TOP MOUNT, 18 GAUGE, 304 STAINLESS STEEL, 25"x21-1/4"x6"(D) SIZE, 3-1/2" dia REAR CENTER DRAIN, REMOVABLE STAINLESS STEEL BASKET STRAINER AND NEOPRENE STOPPER, 1-1/2" 17 GAUGE CHROME PLATED BRASS TAILPIECE, CHROME PLATED CAST BRASS 1/2" TRAP WITH CLEANOUT QUARTER-TURN 3/8" CHROME PLATED HEAVY BRASS ANGLE SUPPLIES AND LOOSE KEY STOPS WITH CHROME PLATED SOFT COPPER RISERS, 4 HOLES, 8" CENTER FOR FAUCET FAUCET- ADA, SINGLE HANDLE WITH SIDE SPRAY, CHROME PLATED ALL BRASS CONSTRUCTION, CONVENTIONAL SWING SPOUT WITH 9" REACH AND AERATOR FLOW OUTLET, LEVER WITH SUPPLIES AT 8" CENTERS, SPRAY HOSE WITH LEVER CONTROL. MAXIMUM FLOW TO BE 1.8 GPM. PROVIDE RESTRICTIVE DEVICE AND ESCUTCHEON.
SK-3/MV-3	SINK	ELKAY	SINK: ELKAY "LUSTERTONE" #LRAD2022260 FAUCET: SLOAN #SF-2150 AERATOR: SLOAN #EAF-22 (CODE 0335021), 1.5 GPM, FIELD INSTALLED	SINK: ACCESSIBLE, ADA SINGLE COMPARTMENT, TOP MOUNT, FAUCET DECK, SINGLE HOLE, 18 GAUGE, 304 STAINLESS STEEL, 16"x16"x6"(D) BOWL SIZE, COMPLETELY UNDERCOATED, 3-1/2" DIAMETER DRAIN OUTLET, REMOVABLE STAINLESS STEEL BASKET STRAINER AND NEOPRENE STOPPER, CHROME PLATED CAST BRASS 1/2" TRAP WITH CLEANOUT, 1-1/2" 17 GAUGE CHROME PLATED BRASS TAILPIECE, QUARTER-TURN 3/8" CHROME PLATED HEAVY BRASS ANGLE SUPPLIES AND LOOSE KEY STOPS WITH CHROME PLATED SOFT COPPER RISERS. FAUCET- ADA, SENSOR OPERATED, BATTERY POWERED, CHROME PLATED, BRASS CONSTRUCTION. PROVIDE FIELD INSTALLED AERATOR INSERT, ADJUSTABLE SENSOR EYE AND UNDERCOUNTER SOLID BRASS MV-3 MIXING VALVE (ASSE 1070), (MIXING VALVE SHALL NOT BE WYE PATTERN STYLE), ADJUSTABLE TEMPERATURE LIMIT STOP AND INTEGRAL CHECK VALVES. SET TEMPERATURE AT 110°F, WATER PROOF CONNECTORS AND CABLE. MOUNT CONTROLS AND BATTERIES IN WATERPROOF VANDAL-RESISTANT ENCLOSURE BELOW SINK, MAXIMUM FLOW TO BE 1.5 GPM. MV-3: LEONARD ECO-MIX MODEL 270-LF-CP MIXING VALVE (ASSE 1070), CHROME PLATED FINISH OR APPROVED EQUIVALENT BY BRADLEY, LAWLOR, POWER. PROVIDE RESTRICTIVE DEVICE.
TPV	TRAP PRIMER VALVE	PRECISION PLUMBING PRODUCTS	PR-500	PPP INC., PRIME-RITE #PR-500 TRAP PRIMER VALVE WITH DISTRIBUTION BOX
UB-1	ICE MAKER OUTLET BOX	GUY GRAY	#BIM875AB	GALVANIZED STEEL ENCLOSURE, LEAD FREE DOMESTIC ANGLE VALVE WITH 1/4" COMPRESSION OUTLET, PROVIDE WATER HAMMER ARRESTOR, WALL-MOUNTED AT 4'-0" AFF. PAINT BOX TO MATCH WALL COLOR.
UR-1	URINAL	AMERICAN STANDARD	URINAL: "WASHBROOK" FLOWISE #6590.001 FLUSH VALVE: SLOAN OPTIMA #8186-1.0	ACCESSIBLE URINAL, WALL HUNG, WHITE, VITREOUS CHINA, ULTRA HIGH EFFICIENCY, ELONGATED 14" RIM FROM FINISHED WALL, EXTENDED SIDES. WASHOUT FLUSH ACTION, 2" OUTLET, 3/4" INLET SPUD FOR FLUSH VALVE, EXPOSED, SENSOR OPERATED, BATTERY POWERED, CHROME PLATE, WALL AND SPUD FLANGES, 1 GPF, OVER-RIDE BUTTON, LOW BATTERY INDICATOR LIGHT, 3 YEAR WARRANTY. FLOOR MOUNTED CARRIER WITH SUPPORTING PLATE.
WC-2	WATER CLOSET	AMERICAN STANDARD	WATER CLOSET: "MADERA" FLOWISE #3043.001 SEAT: BEMIS #3155SSCT FLUSH VALVE: SLOAN #8111-1.6/1.1	ACCESSIBLE WATER CLOSET: ADA, FLOOR MOUNTED, FLUSH VALVE TYPE, WHITE VITREOUS CHINA, SIPHON JET, WATER SAVING, ELONGATED BOWL, 1 1/2" TOP SPUD, BOLT CAPS, TOP OF SEAT AT 17" TO 19" ABOVE FINISHED FLOOR. SEAT: WHITE EXTRA HEAVY OPEN FRONT, INJECTION MOLDED, SOLID ANTI-MICROBIAL PLASTIC SEAT, WITH STAINLESS STEEL OR PLATED STEEL POSTS AND NUTS. FLUSH VALVE: EXPOSED, SENSOR OPERATED, BATTERY POWERED, CHROME PLATED 1" I.P.S. SCREWDRIVER STOP-CHECK VALVE, CHEMICAL RESISTANT MATERIAL, VACUUM BREAKER, WALL AND SPUD FLANGES, DUAL FLUSH, OVER-RIDE BUTTON, RANGE ADJUSTMENT SCREW, LOW BATTERY INDICATOR LIGHT, 3 YEAR WARRANTY.
WCO	WALL CLEANOUT	ZURN	#Z-1441-BP	CAST IRON BODY, GAS AND WATER TIGHT, THREADED BRONZE PLUG, EXTENDED MACHINE SCREWS. PROVIDE ROUND VINYL PAINTABLE ACCESS COVER AT PAINTED WALLS. PROVIDE STAINLESS STEEL COVER AT CERAMIC TILE WALLS.
WF-1	WATER FILLER WITH FILTRATION SYSTEM	MOEN	"SIP" #S5510 FAUCET WITH #9600 CHOICEFLO FILTER	TRADITIONAL BEVERAGE FAUCET AND UNDER SINK WATER FILTRATION SYSTEM, ADA, METAL CONSTRUCTION CARBON BLOCK FILTER TECHNOLOGY, ELECTRIC FILTER LIFE, FLOW SHALL BE LIMITED TO 1 GPM, SYSTEM SHALL BE CERTIFIED TO NSF 61/9, COMPLY WITH FEDERAL SAFE WATER DRINKING ACT, INSTALL FILTER BELOW COUNTER, CERTIFIED TO NSF61/9. COMPLY WITH FEDERAL SAFE WATER DRINKING ACT AND ANSI STANDARD 42. INSTALL AT THE LEFT SIDE OF SINK FAUCET. QUARTER-TURN 3/8" CHROME PLATED HEAVY BRASS ANGLE SUPPLY AND LOOSE KEY STOP WITH CHROME PLATED SOFT, COPPER RISER. PROVIDED RESTRICTIVE DEVISE AND ESCUTCHEON PLATE. PROVIDE 5 YEAR LIMITED WARRANTY AGAINST LEAKS, DRIPS, AND FINISH DEFECTS, FILTER SHALL HAVE 30 DAY LIMITED WARRANTY ON MANUFACTURER'S DEFECTS.

PROVIDE "SAVE WATER" SIGNAGE AT EACH WATER CLOSET WITH DUAL FLUSH VALVE (WC-2)

ACCEPTABLE EQUIVALENTS:
PLUMBING FIXTURES (VITREOUS CHINA) - KOHLER; SLOAN; TOTO.
LAV-2 - KOHLER #K-2007/2005.
SK-1, SK-2 & SK-3 - AMERICAN STANDARD, JUST, KOHLER.
MB-1 - FIAT, WILLIAMS, SWAN, ZURN
EE-1 & MV-1 - GUARDIAN; SPEARMAN.
UB-1 - OATEY
FD-1, FD-3, FCO, AND WCO - J.R. SMITH; WADE; JOSAM; WATTS.
WH-1 - BRADFORD WHITE; BOCK; RHEEM; STATE.
CP-1 - TACO; GRUNDFOSS.
ET-1 - TACO; WESSELS; ELBI; HIRISER.
MV-2, MV-3 - APOLLO; BRADLEY; LAWLOR; POWER; SYMMONS.

DOMESTIC WATER HEATER, EXPANSION TANK, & RECIRCULATION PUMP SCHEDULE		
MARK	DESCRIPTION	COMMENTS
CP-1	RECIRCULATION PUMP	B&G MODEL PL-55B, 3/4" FLANGED CONNECTIONS, 115/60/1, 4.7 AMPS, 2/5 HP, 3250 RPM, BRONZE CONSTRUCTION, PERMANENTLY LUBRICATED SEALED BEARING, MECHANICAL SEAL, DRIP PROOF NON-OVERLOADING MOTOR WITH THERMAL OVERLOAD PROTECTION, UL LISTED, RATED FOR 125 PSIG AT 225°F, 3.0 GPM @ 45 FEET OF HEAD. AQUASTAT: LINE VOLTAGE, ADJUSTABLE 90-180°F WITH STRAP-ON SENSOR BULB, UL LISTED, TRANSFORMER, INSTALLATION PER MANUFACTURER'S REQUIREMENTS.
ET-1	EXPANSION TANK	AMTROL THERM-X-TROL MODEL ST-12C (ASME) DEEP DRAWN STEEL SHELL, HEAVY DUTY BUTYL DIAPHRAGM, ANTI-MICROBIAL POLYPROPYLENE WITH ANTI-LEGIONELLA PROTECTION, STAINLESS STEEL CONNECTIONS, MAX. OPERATING TEMPERATURE 200°F, MAX. WORKING PRESSURE 150 PSI, 1 YEAR WARRANTY, 6.4 GALLON VOLUME TANK, 0.5 MAX. ACCEPTANCE FACTOR, 3/4" DRAIN CONNECTION
WH-1	ELECTRIC WATER HEATER	A.O. SMITH #DRE-80A-18, COMMERCIAL, ASME, 80 GALLON TANK CAPACITY, 18 KW INPUT, 480/60/3, 21.7 AMP FULL LOAD CURRENT, LISTED BY UL AND APPROVED TO NSF STANDARD, EXTRUDED HIGH DENSITY ANODE, GLASSLINED, FRONT PANEL CONTROLS, HIGH TEMPERATURE CUT-OFF SWITCH, BAKED ENAMEL FINISH OUTLET JACKET, FOAM INSULATION, JUNCTION BOX, DRAIN VALVE, ASME RATED T&P RELIEF VALVE, 3-YEAR LIMITED WARRANTY, 74 GPH @ 100°F TEMPERATURE RISE, 140°F DISCHARGE

MASTER MIXING VALVE		
MARK	MANUFACTURER	COMMENTS
MV-2	LEONARD ECO-MIX #TM-26-LF-E-RF-BDT	THERMOSTATIC MIXING VALVE FOR TEMPERED WATER CONTROL, BRONZE CONSTRUCTION, ROUGH BRASS FINISH, UNION INLETS WITH STRAINERS AND CHECK STOPS, DIAL THERMOMETER ON OUTLET, ADJ. HIGH TEMPERATURE LIMIT STOP SET FOR 120 deg F. VALVE RATED FOR 13 GPM @ 15 PSI SYSTEM PRESSURE DROP AND 1 GPM MINIMUM FLOW, PROVIDE HOT WATER RETURN CONNECTION. PROVIDE SURFACE MOUNTED 18 GA PAINTED STEEL CABINET WITH 16 GA PAINTED STEEL LOCKING DOOR TO ENCLOSE VALVE.

PLUMBING CALCULATIONS

(BASED ON 2018 INTERNATIONAL PLUMBING CODE)

FIXTURE MARK	FIXTURE	COUNT	CW	TOTAL CW	HW	TOTAL HW	CW+HW	TOTAL CW+HW	DFU	TOTAL DFU
BF-1	BOTTLE FILLER	3	0	0	0	0	0	0		0
DISHWASHER	DISHWASHING MACHINE	1	0	0	1.4	1.4	1.4	1.4	2	2
EE-1/MV-1	SWING-AWAY EYEWASH/MIXING VALVE	4	0	0	0	0	0	0		0
EW-1	BOTTLE FILLER STATION WITH BI-LEVEL COOLER	1	0.5	0.5	0	0	0.5	0.5	1	1
FD-1	FLOOR DRAIN	1	0	0	0	0	0	0	0	0
FD-3	FLOOR DRAIN	1	0	0	0	0	0	0	6	6
HB-1	WALL HYDRANT	2	3	6	0	0	3	6		
LAV-2/MV-3	LAVATORY	4	1.5	6	1.5	6	2	8	1	4
MB-1	MOP BASIN	1	2.25	2.25	2.25	2.25	3	3	5	5
SK-1/MV-3	SINK	2	1.5	3	1.5	3	2	4	2	4
SK-2/GD-1	SINK/GARBAGE DISPOSER	1	1.5	1.5	1.5	1.5	2	2	2	2
SK-3/MV-3	SINK	3	1.5	4.5	1.5	4.5	1	3	2	6
UB-1	ICE MAKER OUTLET BOX	2		0		0	0	0		0
UR-1	URINAL	4	5	20	0	0	5	20	2	8
WC-2	WATER CLOSET	4	10	40	0	0	10	40	4	16
WF-1	WATER FILLER WITH FILTRATION SYSTEM	1		0		0		0		0
	SPACE TOTAL, FU			83.75		18.65		87.9		54
	DEMAND FLOW RATE, GPM			62		19		64		5
	EMERGENCY EYEWASH, GPM			0.8		0.8		0.8		
	PEAK DEMAND FLOW RATE, GPM			62.8		19.8		64.8		

FIXTURE ELEVATION _____ 3 FEET

(3 FT) x 0.43 = 1.29 = 2.0 PSI STATIC LOSS

HORIZ. PIPE LENGTH TAP TO BLDG METER _____ N/A

HORIZ. PIPE LENGTH METER TO SPACE (BIOLIFE) _____ 13 FEET

HORIZ. PIPE LENGTH BLDG TO LAST FIXTURE _____ 281 FEET

VERT. PIPE LENGTH BLDG. RISE TO FIXTURE _____ 3 FEET

TOTAL PIPE LENGTH _____ 297 FEET

(297 FT) x 1.25 (FITTING LOSS) = 371 = FEET TOTAL DEVELOPED LENGTH

SIZE	DEVICE	PSI LOSS
2"	BACKFLOW PREVENTER	10.0
1-1/2"	METER	3.0
	STATIC	2.0
	FIXTURE (WATER CLOSET)	35.00

TOTAL BUILDING LOSS _____ 50 PSI

PRESSURE AT BLDG _____ 65 PSI

PRESSURE REGULATOR SETTING _____ N/A

BUILDING LOSS _____ 50 PSI

DIFFERENCE _____ 15 PSI

(15 PSI/371 FT) x 100 FT = 4 PSI MAX. PSI DROP ALLOWABLE PER 100 FT. PIPE LENGTH

BRANCH WATER PIPE SIZING CHART - 5 PSI LOSS

PIPE SIZE	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"
GPM	2.5	6.5	14	24	38	77
WSFU	1	3	5	10	25	140


FLOW TEST
THE CONTRACTOR SHALL PROVIDE CURRENT FLOW TEST. 65 PSI STATIC PRESSURE IS USED FOR CALCULATIONS.

DRAWING INDEX - PLUMBING

P110	UNDERFLOOR PLAN - PLUMBING
P111	FIRST FLOOR PLAN - PLUMBING
P121	ENLARGED PLANS - PLUMBING
P201	SANITARY - VENT RISER DIAGRAM
P203	DOMESTIC WATER RISER DIAGRAM
P301	PLUMBING DETAILS
P501	PLUMBING MATERIAL LIST



Design and construction documents as instruments of service are given in confidence and remain the property of Onyx Creative. The use of this design and these construction documents for purposes other than the specific project named herein is strictly prohibited without expressed written consent of Onyx Creative.



Approved by Tommy Hahn
04/12/2023 7:43:16 AM

BioLife® PLASMA SERVICES
BIOLIFE
4731 VALLEY VIEW BLVD.
NW ROANOKE, VA 24012

Project No.: 20474

Drawn By: IEU

Date: 2022-11-18 Issue: FOR PERMIT

2023-04-03 5 ITC 4

P501

PLUMBING MATERIAL LIST