

March 5, 1974

Chief Carl C. Holt
Roanoke Fire Department
13 Church Avenue, S. E.
Roanoke, Virginia

Dear Sir:

This is to advise that we have installed a fire hydrant on the southeast corner of Bluemont Avenue & Winborne Street, S. W. This hydrant is now ready for service.

FIRE HYDRANT SET										
COR.	MAKE	SIZE	H. FACES	TO MAIN	VALVE	VAULT	BOX	H.TOV.	HOZZ.	LB. PRESS.
S.E.	Muel.	4"	Bluemont	8"	6"	x	#2	6'	3	35

Very truly yours,

D. T. Maxey
Distribution Supt.

DTM/aec

cc: ✓ Charlie Harlow, Engr. Dept.
Ann Mundy
W. D. Billing