



3. ALL PIPE CONNECTING TO TANK WALL SHALL BE DUCTILE STEEL AND SHALL BE CONTINUOUSLY WELDED ON BOTH SIDES OF TANK AND SHALL NOT LEAK.