

NOTE: ALL PROPOSED SEWER LINES TO BE 8" IN DIAMETER

NOTE: SEWER LINES ARE LAID AT SUCH DEPTHS AS TO SERVE GROUND FLOOR PLUMBING ONLY AND TO PICK UP SEPTIC TANK DISCHARGE LINES.

NOTE: 1000 GRID BASED ON VIRGINIA STATE COORDINATE SYSTEM 1929 DATUM VERTICAL DATUM 1929 G.A.

NOTE: BEFORE STARTING CONSTRUCTION THE CONTRACTOR SHALL CONTACT THE HIGH VOLTAGE DIVISION OF THE VIRGINIA POWER CO. TO LOCATE ALL POWER LINES AT 700-344-6551

NOTE: BEFORE STARTING CONSTRUCTION THE CONTRACTOR SHALL CONTACT THE HIGH VOLTAGE DIVISION OF THE VIRGINIA POWER CO. TO LOCATE ALL POWER LINES AT 700-344-6551

NOTE: ROCK QUANTITIES ARE THE ENGINEER'S ESTIMATE ONLY. THEY ARE TO BE USED BY THE CONTRACTOR AS AN AID TO PRICING THE LINEWORK.

NOTE: REFERENCE DRAPER ADEN ASSOCIATES, INC. WATER SYSTEM PLANS 175-194 TO THE LOCATION OF EXISTING WATER LINES.

NOTE: THERE SHALL BE A MINIMUM HORIZONTAL SEPARATION OF 10' BETWEEN SEWER LINES AND A MIN VERTICAL SEPARATION WHERE SPECIFIED.

DROP MANHOLES THIS SHEET:
#34, #119

