




DESIGN CRITERIA --- WASTEWATER TREATMENT PLANT

*Note: INFORMATION & DATA SHOWN ON THIS SHEET REPRESENTS "DESIGN" CRITERIA. OTHER SHEETS IN THIS SET OF PLANS SHOW "AS-BUILT" DIMENSIONS.

TREATMENT OBJECTIVE

POPULATION EQUIVALENT = 750 PERSONS BY YEAR 2000.
HYDRAULIC LOADING OF 100 GALLONS PER PERSON = 75,000 GPD
WASTEWATER CHARACTERISTICS = AVERAGE MUNICIPAL SEWAGE.
INFLUENT STRENGTH = 240 MG/L BOD₅ AND SUSPENDED SOLIDS.
EFFLUENT STRENGTH = 30 MG/L BOD₅ AND SS = 87.5% REMOVAL.
EFFLUENT DISSOLVED OXYGEN CONCENTRATION = 6.50 MG/L.
EFFLUENT CHLORINE RESIDUAL CONCENTRATION = 2.0 MG/L
DISCHARGE TO CATAWBA CREEK, JAMES RIVER BASIN

INFLUENT MANHOLE

RECEIVES WASTEWATER FROM GRAVITY COLLECTION SYSTEM.
RECEIVES RETURN SLUDGE FROM CLARIFIERS AND CHLORINE TANKS.
PROVIDES ACCESS TO RAWSEWAGE FOR SAMPLING.
PROVIDES REMOVAL OF FLOATING SOLIDS AND RAGS.

AERATED LAGOON

CONFIGURATION: 4 CELLS IN SERIES 75 DAYS DETENTION EACH
BERMS SLOPED 3:1 INSIDE AND OUT WITH REVENTMENT GRIDS TO PREVENT EROSION
RECYCLE OF MIXED LIQUOR SUSPENDED SOLIDS FROM CLARIFIERS.
AERATION IS PROVIDED BY 6000 FT. OF SLOTTED TUBING.
OXYGEN REQUIRED = $DLP \cdot G \cdot 2.84 \cdot 10^{-4} \cdot 0.875 = 8.05 \text{ #/HR}$ (WHERE D=INFLUENT BOD₅, L=COMPARATIVE ULTIMATE BOD, P=PERCENT REMOVED)
TRANSFER RATE = $R_a(C_{sw}-C_r) \cdot (1.024^{T-20}) \cdot (A) = 3(763-20) \cdot (1.024^{75-20}) \cdot (0.8) = 1087 \text{ #/HR}$

WHERE R_a =AERATOR TRANSFER RATE, C_{sw} =OXYGEN SATURATION LEVEL,
T=OPERATING TEMP, C_r =RESIDUAL O₂ CONC, A=WASTEWATER TRANSFER COEF.
FICIENT
BLOWER HORSEPOWER = $NOR/PS = 8.05/1087 = 7.40 \text{ HP}$
BLOWERS PROVIDED - 2 - 7 1/2 HP WITH 120 FT³/MIN AGAINST 9 PSIG CAPACITY
BOD₅ REMOVED = 87.5% = 131.4 #/DAY

SLUDGE PRODUCTION

TOTAL SUSPENDED SOLIDS = 240 MG/L (180 MG/L ORGANIC, 60 MG/L INORGANIC)
DESTRUCTION = 83% ORGANIC, 0% INORGANIC = 30.6 MG/L ORGANIC + 60 MG/L INORGANIC
SLUDGE PRODUCTION = $90.6 \text{ MG/L} \times 8.34 \text{ #/MG} \times 0.075 \text{ MG} = 56.6 \text{ #/DAY}$
VOLUME OF SLUDGE = $\frac{56.6}{2.5(1.35)62.4} + \frac{1.25(10)62.4}{1.35(10)62.4} = 31.4 \text{ FT}^3/\text{DAY} = 1125 \text{ FT}^3/\text{YR} = 0.37\% \text{ LAGOON VOL.}$

CLEANING REQUIREMENTS = AT SLUDGE VOLUME = 10% = EVERY 26 YEARS

SECONDARY CLARIFIER

DUPLEX SQUARE HOPPER BOTTOMED UNITS WITH INTERMITTANT SLUDGE RECYCLE.
DETENTION TIME = 1 HR 32 MIN, SURFACE SETTLING RATE = 586 GPD/FT² OVERFLOW RATE = 4688 GPD/FT²

CHLORINE CONTACT TANK

SINGLE CIRCULAR HOPPER BOTTOMED TANK WITH INTERMITTANT SLUDGE RETURN
DETENTION TIME = 30 MIN CHLORINE RESIDUAL = 2.0 MG/L
CHLORINE FEED CAPACITY = 25 #/DAY = 40 MG/L

CASCADE AERATION STEPS

DEFICIT RATIO = $R = 1 + 0.11AS(1 + 0.046T) \cdot \frac{\sqrt{C_s - C_a}}{C_s - C_a}$
WHERE C_s =O₂ SATURATION AT CRITICAL TEMP, ELEV = 763 MG/L, C_a =O₂ CONC BELOW STEPS
B=1/3 T=20°C, H=10', N=400 STEPS C_a =O₂ CONC ABOVE STEPS, A=0.8
BY CALCULATION N=822, THEREFORE 9 STEPS ARE PROVIDED

SLUDGE RETURN PUMPS

DUPLEX SUBMERSIBLE PUMPS, 2HP RATED AT 100 GPM AGAINST 20 FEET TDH

FLOW MEASURING EQUIPMENT

CONTROL SECTION = 45" FIBERGLASS V-NOTCH WEIR
EQUIPMENT INCLUDES FLOAT ACTIVATED TRANSMITTER AND TOTALIZING,
INDICATING, AND RECORDING RECEIVER.

100 YEAR FLOOD ELEVATION - 1042.0

A-Bills