



ALL SEWER LINES SHALL BE CONSTRUCTED OF ANSI/AWWA APPROVED WATER PIPE, HYDROSTATICALLY PRESSURE TESTED IN PLACE WITHOUT LEAKAGE PRIOR TO BACKFILL. PRESSURE TEST SHALL BE AT 30 PSI. IN NO CASE SHALL THE SEPARATION BETWEEN THE SEWER AND WATER LINE BE LESS THAN SIX INCHES (6").