

Sanitary Sewer Data Sheet  
(To Be Included with ALL Plan Submittals)

Date of Plan Approval (Completed by WVWA):

Date of Plan Submittal: 08/27/09

Project Title: CVS/pharmacy Store #7503

Alternate Project Titles:

Project Location: Street: 3909 Challenger Avenue

Tax Parcel Number(s): 050.01-01-03.00-0000

No. Structures/Building/Units: 1

Design Flows (Both average and peak)

Average(GPD): 98

Peak(GPB): 9.68 GPM

Pipe Material (if known): SDR-35 PVC

Pipe Diameter: 6" (lateral to CVS), 8" (extension)

Total Length: 1100 ft


Comments/Clarifications:

Submitted by: Ryan Ritterskamp, P.E.

Engineering Firm: Kimley-Horn and Associates, Inc.

Telephone Number: 804-673-3882

Attach all sewer calculations




Kimley-Horn  
and Associates, Inc.  
1500 FOREST AVENUE, SUITE 115  
RICHMOND, VIRGINIA 23229

CONSULTANT:

KIMLEY-HORN AND ASSOCIATES, INC.  
1500 FOREST AVENUE, SUITE 115  
RICHMOND, VA 23229  
PHONE: (804) 673-3882  
FAX: (804) 673-3980

SEAL:



CVS/  
pharmacy

13,225 S.F. PROTOTYPE

STORE NUMBER: 7503

INTERSECTION OF  
ROUTE 460 & ROUTE 610  
ROANOKE, VIRGINIA

OWNER/DEVELOPER:

THE REBKEE COMPANY  
15871 CITY VIEW DRIVE, SUITE 300  
MIDLOTHIAN, VA 23113  
PHONE: (804) 419-0740  
FAX: (804) 419-0759

REVISIONS:

LAYOUT COORD: RRP

PLANNING MGR. DBE

DRAWING BY: DHL

DATE: 11/12/09

JOB NUMBER: 113001106

TITLE:

UTILITY DETAILS

SHEET NUMBER:

CU-502

COMMENTS: