

Water Information

Project Name	Christian Ave. & Trinkle Ave. Waterline Replacement
Install Contractor	Wells Construction Co.
Install Date	8/7/2019
	Water Main
Manufacturer	U.S. Pipe
Diameter	8
Pipe Class	C151 Class 350
Material	Ductile Iron (DIP)
Comments	
	Water Main
Manufacturer	U.S. Pipe
Diameter	6
Pipe Class	C151 Class 350
Material	Ductile Iron (DIP)
Comments	
	Water Service(s)
Manufacturer	ADS Poly Flex
Diameter	1
Pipe Class	PE4710
Material	High Density Polyethylene(HDPE)
Comments	
	Water Valve
Manufacturer	American Flow Control (AFC)
Valve Type	Gate-Resilient Seat
Diameter	8
Direction to Open / Turns to Close	Left / 27
Comments	
	Water Valve

Water Information

Manufacturer	American Flow Control (AFC)
Valve Type	Gate-Resilient Seat
Diameter	6
Direction to Open / Turns to Close	Left / 21
Comments	
	Hydrant
Authority ID #	12862
Manufacturer	Darling
Model	B84B-5
Cast Date	2019
Static Pressure	80
Comments	