

1. CONTRACTOR SHALL NOT INTERCONNECT THE EXISTING TRAILER COURT WATER SYSTEM WITH THE NEW WATER SYSTEM. INDIVIDUAL SERVICE SWITCH OVERS SHALL BE ONLY AFTER ENTIRE NEW SYSTEM IS IN SERVICE AND APPROVED FOR USE. THE EXISTING TRAILER COURT SYSTEM SHALL BE ABANDONED IN PLACE.
2. ALL VALVE BOX AND BLOW OFF ASSEMBLY TOPS SHALL BE RECESSED A MINIMUM OF 2" BELOW GRADE.

BID ITEM #1

CRAIG-NEW CASTLE P.S.A.
WATERLINE EXTENSION &
SANITARY SEWER REHABILITATION
CRAIG COUNTY, VIRGINIA

LMW P.C.
ENGINEERING • ARCHITECTURE • SURVEYING
(540) 345-0675
FAX (540) 342-4456
102 ALBEMARLE AVE., S.E.
ROANOKE, VIRGINIA 24013

DRM	BY	DESCRIPTION	DATE	NO.
DRM		VDH COMMENTS	5-31-00	1
DRM		VDOT COMMENTS	5-31-00	2
DRM		VDH COMMENTS	7-13-00	3
WATERLINE EXTENSION PLAN RTE. 311				
DESIGNED BY	DME/ETH			
DRAWN BY	ETH			
CHECKED BY	DRM			
APPROVED BY	DRM			
SUBMITTED BY	DRM			
DRAWING/563-WL-MASTER				
DATE	6/8/00			
SCALE	1"=30'			
COMMISSION NO.	1563			
SHEET	7	OF 14		