

LOCATION

DELRAY PUMPING STATION
4828 Delray Street, N. W.

UNIT NO.	PUMP NO. 1	PUMP NO. 2	PUMP NO. 3
Make	Worthington 4L3	DeLaval - Type K	DeLaval - Type K
G.P.M.	695	1390	2780
Serial No.	1405471	702694	702693
Size	6"S x 4"D	6"S x 5"D	10"S x 8"D
Suct. Pres.	-9	-9	-9
Disc. Pres.	65	65	65
T.D.H.	175	175	175
Storage	Tanks & Res.	Tanks & Res.	Tanks & Res.
Make Motor	G.E.	G.E.	G.E.
Serial No.	WH6955475	VY362651	SY234033
H.P.	50	100	200
Voltage	220/440	220/440	440
Amp. F.L.	120/60	260/130	235
Amp. Fuse	200 Fuse	200 Breaker	400 Breaker
Phase	3	3	3
R.P.M.	1765	1770	1770
Control	Automatic	Automatic.	Automatic
In-C Line	Overhead	Overhead	Overhead
Elev. Pump	Approx. 1100'		
Max.Elev.Serv.			
Storage Elev.			
Purchased			

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE
Pump No. 1 Ward Leonard Starter						
Pump 2 & 3 G.E. Starter						
Autocon Pump 1 & 2						
Pump 3 telephone circuit to Eugene						
Dr. tank						
BIF Transmitter & receiver						

REMARKS: