

NOTES:

- EXISTING CLA—VAL FLOW CONTROL VALVES SHALL BE REBUILT OR REPLACED. REBUILDING OF VALVES SHALL INCLUDE REPLACEMENT OF ALL COMPONENTS OTHER THAN VALVE BODY.
- 2. CONCTRACTOR SHALL CUT EXISTING METAL WALL PANELS AND INSTALL LOUVERS AND FAN AT LOCATIONS SHOWN. LOUVER AND FAN UNITS SHALL BE PROVIDED WTH FLANGES TO COVER EDGES OF WALL OPENING AND SHALL BE SEALED TIGHTLY AGAINST WALL PANEL. CONTRACTOR SHALL PROVIDE ADDITIONAL STRUCTURAL MEMBERS AS NECESSARY TO SUPPORT FAN AND LOUVERS.

Virginia - North Carolina - Tennessee

100 Ardmore Street Blacksburg, Va. 24060 540-552-5592

DATE : 08 SEP 04 DESIGNED: RNJ DRAWN : RNJ CHECKED : CSF

REVISIONS: RECORD