

Water main 4 ft off side of Rd. on Anchor Dr.

Match Mark sheet 1

Driveway to Clubhouse

1" Bay
4 ft off side
Anchor Dr.
2" Gate Valve
Water line 4 ft off
side of road

Well Lot No. 2
T# 0310405400
289 Anchor Drive

2" water line

Req'd:
1-8"x2"x8" Tee
1-2" Gate Valve

Req'd:
2-8"x6"x8" Tees
2-8" gate valves
2-6" gate valves
1-8" to 6" reducer

Match Mark Sheet 3

Match Mark This Sheet

STARBOARD LANE
3" Water Main

1" service connection

1" service connections

Required:
45 1-3" to 2" Reducer
1-2" Gate Valve
1-2" line to atmosphere screened

Required:
1-Fire Hydrant Assembly

6" Water Main
LARBOARD DRIVE

LARBOARD DRIVE

Meter box 7' to 1/2 side of pin
Value is 90' from C/box

Top for Maint Bldg
is at 108'

Main line off point
From Valve on starboard Ln.

25' = 10'	400' =
50' = 9' 6"	425' =
75' = 9'	450' =
100' = 8'	475' =
125' = 8'	500' =
150' = 7' 6"	525' =
175' = 6' 6"	550' =
200' = 5'	575' =
225' = 5'	600' =
250' = 4' 6"	
275' = 4' 2"	
300' = 4' 2"	
325' = 4' 6"	
350' = 5'	
375' = 4' 6"	

Required: Fire Hydrant Assembly

STARBOARD LANE

6" to 3" Reducer

Match Mark This Sheet

WATER SYSTEM
to serve
WATER FRONT SECTION 2
owned by
BREMBLE PROPERTIES, INC.
GILLS CREEK MAG. DIST.
FRANKLIN COUNTY, VIRGINIA

Prepared by: William L. Law, Civil Engineer, Va. Cert. No. 1296
Route 1, Box 420, Bassett, Virginia 24055
July 10, 1978

Scale: 1 inch = 50 feet

