

[illegible]

SS-100 SEWER PROFILE

NOTE:
ALL DUCTILE IRON PIPE TO BE LINED WITH PROTECTO 401 OR APPROVED EQUAL.

Key features and data points from the profile:


- SSMH 100:** STA: 11+50, Rim Elev: 898.21, Invert Elev: 890.04, Invert In: 888.34
- SSMH 101:** STA: 14+97.23, Rim Elev: 910.10, Invert Elev: 908.89, Invert Out: 908.79
- Pipe Segments:**
 - 150.00' - 8" DIP @ 1.00%
 - 347.23' - 8" SDR-35 @ 3.07%
 - 300.00' - 8" SDR-35 @ 1.00%
- Handwritten Notes:**
 - 8 FT Deep
 - 34 FT
 - 9.40 FT Deep
 - Provide 4' Diameter Concrete MH with Concrete Fill. See Detail on Sheet C3.10

NOTE: 

ALL DUCTILE IRON PIPE TO BE LINED WITH PROTECTO 401 OR APPROVED EQUAL.

20
100
MATCHLINE SHEET C3.2

Rev	Description	Date	By
1	Chg'd MH from 3' to 4'	6/19/12	LBR
Designed: DMV			
Drawn: LBR			
Checked: JGR			
Approved: DMV			
Date:		4/27/12	
Project:		WSE	
C3.1 Sheet 4 of 10			

WESTLAKE SEWER EXTENSION PHASE 1	GRAVITY SEWER SS100 PLAN & PROFILE
	
ENGINEERING SERVICES 601 S JEFFERSON ST, SUITE 300 ROANOKE, VA 24011 540-853-5641	WESTERN VIRGINIA WATER AUTHORITY

C3.1
Sheet 4 of 10