



PLAN WATER MAIN
SCALE: 1"=100'-0"
SECTION "2"

- GENERAL NOTES
1. UTILITY LINES SHOWN ON DRAWINGS ARE DIAGRAMMATIC ONLY, THE LOCATION OF EXISTING UTILITIES ARE TO BE ASCERTAINED IN THE FIELD PRIOR TO CONSTRUCTION.
 2. STUBBED WATER MAINS SHALL BE EXTENDED THREE (3) FULL LENGTHS OF PIPE BEYOND THE GATE VALVE PRIOR TO BEING PLUGGED AND BLOCKED.

PLAN WATER MAIN
SCALE: 1"=100'-0"
SECTION "1"

DATE	REV.	DESCRIPTION	BY
		PLAN WATER MAIN	
		WATER MAIN EXTENSION FROM GRANDIN ROAD TO VIRGINIA ROUTE 419 ROANOKE, VIRGINIA	
		CITY OF ROANOKE OFFICE OF CITY ENGINEER ROANOKE, VIRGINIA	
		CONTRACTOR MUST VERIFY ALL DIMENSIONS AT PROJECT BEFORE PROCEEDING WITH WORK	
		CITY ENGINEER	
		CHECKER	
		APPROVED	
		DATE	
		JOB NO.	
		SHEET	
		OF	