



(6) 4" SCH. 40 PVC CONDUITS W/ L.R. BEND FOR FUTURE ANTENNA CABLES THROUGH RINGWALL AND CONCRETE FLOOR. BOTH ENDS OF EACH CONDUIT SHALL BE CAPPED. EXTEND EACH CONDUIT A MINIMUM OF 12" ABOVE CONCRETE FLOOR.



AS BUILT 3/8/17



GREEN RIDGE WATER STORAGE TANK

TANK ELECTRICAL

Rev	Description	Date	By
1	TANK NOTES	3-31-15	

Designed:	TEC
Drawn:	TEC
Checked:	RWB
Approved:	
Date:	2-13-15
Project:	