

ALL COSTS GIVEN ARE COMPLETE IN PLACE				
DESCRIPTION	UNIT	QUANTITY	UNIT COST	TOTAL COST
CLEARING & GRUBBING	LS		\$	\$
EXCAVATION	CY			
EMBANKMENT	CY			
FENCING	LF			
STRUCTURES				
ACCESS ROAD				
AS-BUILTS				
SUB-TOTAL				\$
10% CONTINGENCY				\$
TOTAL PROJECT COST				\$

DESIGN ELEVATIONS WITH EMERGENCY SPILLWAY

DESIGN HIGH WATER (25-YR. STORM ELEV.)

67 C.Y./AC. "DRY" STORAGE

67 C.Y./AC. "WET" STORAGE

SEDIMENT CLEANOUT POINT

MIN. 2:1

MIN. 3:1

0.5'

1.0'

RISE CRIST

DEWATERING DEVICE

\* Gravel shall be VDOT #3, #357 or #5 coarse aggregate.

(P) GRAVEL AND WIRE MESH DROP INLET SEDIMENT FILTER

This method of inlet protection is applicable where heavy flows are expected and where an overflow capability and ease of maintenance are desirable.

2 ACRES OR LESS OF DRAINAGE AREA

2-10 ACRES OF DRAINAGE AREA

FILTER CLOTH (OPTIONAL)

DOWNSTREAM VIEW

VIBOT #1 COARSE AGGREGATE

FLUW

2'

3'

2'

CD

ROCK CHECK DAM

CLASS 1 RIPRAP

**SPECIFIC APPLICATION**

This method of inlet protection is applicable at curb inlets where ponding in front of the structure is not likely to cause inconvenience or damage to adjacent structures and unprotected areas.

■ Gravel shall be VDOT #3, #57 or 5 coarse aggregate.

The diagram illustrates the operation of a sedimentation tank. At the top, a plan view shows water flowing from left to right through a rectangular tank, with arrows labeled 'FLOW'. The main cross-section shows water entering from the left. A vertical line indicates the 'AS REQUIRED' water level. The bottom of the tank is sloped, labeled 'MAX. SLOPE 2:1'. A central vertical pipe is labeled 'DEPT. BELOW TOP OF INLET MIN. 1'-MAX. 2'' and 'DEWATERING'. A horizontal pipe at the bottom is labeled 'DRAIN INLET'. A section of the tank bottom is labeled 'WEEP HOLES FOR'. A note on the right states 'LARGER PARTICLES WILL SETTLE'. A section of the tank bottom is labeled 'STORM WATER WITH LARGER PARTICLES REMOVED'.

The diagram illustrates a cross-section of a temporary diversion structure. Key components and labels include:

- 18" MDL:** Minimum Depth Limit, indicated on the left side of the structure.
- COMPACTED SILL:** The top surface of the diversion structure.
- FLDN:** Full Depth Notation, indicated on the right side of the structure.
- 4.5' MDL:** Minimum Depth Limit, indicated at the base of the structure.

Below the cross-section, five flow paths are shown, each with a circular icon and a descriptive label:

- DD:** TEMPORARY DIVERSION DIKE (represented by a single arrow pointing right).
- FD:** TEMPORARY FILL DIVERSION (represented by two arrows pointing right).
- RWD:** TEMPORARY RIGHT-OF-WAY DIVERSION (represented by two arrows pointing right).
- DV:** DIVERSION (represented by two arrows pointing right).

Wire

Post

Filter Fabric

Extend Fabric and Wire Into Trench

4'

4.0'

1.0'

CROSS-SECTION

10' IF WIRE USED  
6' IF WIRE NOT USED

FLOW

**Plan**

**Section A-A**

**Plan**

**Section A-A**

**Notes**

1. Apron lining may be rip-rap, grouted rip-rap, or concrete.
2.  $L_a$  is the length of the rip-rap apron as calculated in Tables 13.66 and 13.67.
3.  $d = 1.5$  times the maximum stone diameter, but not less than 6".

■ SEE PLATE 313-I

CLASS I RIP-RAP

COARSE AGGREGATE

FILTER CLOTH

EXCAVATED AREA

Length(ft) =  $6 \times \text{Drainage Area (ac.)}$

DIVERSION DIKE

■ COARSE AGGREGATE SHALL BE VDOT #3, #357 OR #43

8T SEDIMENT TRAP

[illegible]

A cross-sectional diagram of a roadside ditch. The ditch is 20' wide at the top and 10' deep. The bottom is 6' wide. The ditch is lined with a 10' wide area of 10' min. depth. The ditch is labeled 'Ditch to Sediment Basin or Trap'. The ditch is adjacent to a 'HARD SURFACE PUBLIC ROAD' which is 10' wide. The ditch is 20' wide at the top and 10' deep. The bottom is 6' wide. The ditch is lined with a 10' wide area of 10' min. depth. The ditch is labeled 'Ditch to Sediment Basin or Trap'.

The diagram illustrates a temporary gravel construction entrance. The top portion is a cross-section showing a gravel layer on top of a filter cloth, which is supported by a concrete structure. A label 'VDGT #1 Coar. Aggregate' points to the gravel. Below the cross-section is a plan view of the entrance, showing a rectangular area with a '12' MIN.' dimension across the top. The entrance is filled with gravel, and a 'FILTER CLOTH' is indicated. The sides of the entrance are labeled '3' MIN.' and '3' MIN.'. A 'Reinforced Concrete' structure is shown at the bottom of the plan view. A 'Drain Space' is indicated on the left side. A note states 'WASH RACK DETAIL (IF REQUIRED)'. A legend at the bottom left shows a circle with 'CE' inside, labeled 'TEMPORARY GRAVEL CONSTRUCTION ENTRANCE'.

CE

TEMPORARY GRAVEL CONSTRUCTION ENTRANCE

1. ALL SOIL EROSION & SEDIMENT CONTROL MEASURES SHALL BE ACCOMPLISHED IN STRICT ACCORDANCE WITH THE STANDARDS AND SPECIFICATIONS CONTAINED IN THE VIRGINIA EROSION AND SEDIMENT CONTROL HANDBOOK, LATEST EDITION.
2. THE APPROVING AUTHORITY MAY ADD TO, DELETE, RELOCATE, CHANGE, OR OTHERWISE MODIFY CERTAIN EROSION AND SEDIMENT CONTROL MEASURES WHERE FIELD CONDITIONS ARE ENCOUNTERED THAT WARRANT SUCH MODIFICATIONS.
3. ALL SOIL EROSION AND SEDIMENT CONTROL MEASURES AS SHOWN ON THE PLAN SHALL BE PLACED IN ADVANCE OF THE WORK BEING PERFORMED, AS FAR AS PRACTICAL.
4. IN NO CASE DURING CONSTRUCTION SHALL WASTE RUNOFF BE DIVERTED OR ALLOWED TO FLOW TO LOCATIONS WHERE ADEQUATE PROTECTION HAS NOT BEEN PROVIDED.
5. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO LEAVE THE SITE ADEQUATELY PROTECTED AGAINST EROSION, SEDIMENTATION, OR ANY DAMAGE TO ANY ADJACENT PROPERTY AT THE END OF EACH DAY OF CONSTRUCTION.
6. FOR THE EROSION CONTROL SYMBOLS SHOWN ON THE PLANS, REFER TO THE VIRGINIA UNIFORM CODING SYSTEM FOR EROSION AND SEDIMENT CONTROL PRACTICES CONTAINED IN THE VIRGINIA EROSION AND SEDIMENT CONTROL HANDBOOK, LATEST EDITION. THESE SYMBOLS SHALL BE KEPT TO BE UTILIZED ON ALL EROSION CONTROL PLANS SUBMITTED TO BUREAU COUNTY.

TYPE A		TYPE B (SLOPES 3:1 OR STEEPER)	
15 OCTOBER TO 1 FEBRUARY K-31 FESCUE @ 5 LB / 1000 SF JERZY WINTER RYE @ 1/2 LB / 1000 SF		MARCH TO 1 MAY CROWN VETCH @ 1/2 LB / 1000 SF PERENNIAL RYEGRASS @ 1/2 LB / 1000 SF RED TOP @ 1/8 LB / 1000 SF	
1 FEBRUARY TO 1 JUNE K-31 FESCUE @ 5 LB / 1000 SF ANNUAL RYE @ 1/2 LB / 1000 SF		1 JUNE TO 1 OCTOBER CROWN VETCH @ 1/2 LB / 1000 SF PERENNIAL RYEGRASS @ 1/2 LB / 1000 SF RED TOP @ 1/8 LB / 1000 SF	
1 JUNE TO 1 SEPTEMBER K-31 FESCUE @ 5 LB / 1000 SF GERMAN MILLET @ 1/2 LB / 1000 SF			
1 SEPTEMBER TO 15 OCTOBER K-31 FESCUE @ 5 LB / 1000 SF ANNUAL RYE @ 1/2 LB / 1000 SF			
LIME	140 LB / 1000 SF PULVERIZED AGRICULTURAL LIMESTONE		
FERTILIZER	50-20-0 @ 25 LB / 1000 SF 38-0-0 @ 7 LB / 1000 SF		
MULCH	IF REQUIRED, SHALL BE USED OVER ALL SEEDED AREAS AND SHALL BE APPLIED IN ACCORDANCE WITH SECTION 1.75 OF THE VIRGINIA EROSION AND SEDIMENT CONTROL HANDBOOK, LATEST EDITION.		
SOIL CONDITIONING	INCORPORATION OF LIME AND FERTILIZER, SELECTION OF CERTIFIED SEED, MULCHING, MAINTENANCE OF NEW SEEDLINGS, AND RESEEDING SHALL BE IN ACCORDANCE WITH SPECIFICATIONS CONTAINED WITHIN THE VIRGINIA SOIL EROSION AND SEDIMENT CONTROL HANDBOOK, LATEST EDITION. ADDITIONAL SEEDING TO BE PERFORMED AS REQUIRED BY THE INSPECTOR.		
SEED APPLICATION	APPLY SEED UNIFORMLY WITH A CYCLONE SEEDER, DRILL, CULTIPADDER SEEDER, OR HYDROSEEDER IN A FIRM, FRABLE, SEEDBED. MAXIMUM SEEDING RATE SHALL BE 1/4 INCH.		

TOTAL DISTURBED AREA = 1.08 AC. = 47,081 SQ. FT.

2	CO. 9-7-05, CITY 9-1-05 COM.	DRB	JDE	9-14-05
1	REV. PER CO. COMMENTS 7/25/05	DRB	JDE	8-23-05

1	ENGR. & INSPEC.	04-10-93
2	ENGR. & INSPEC.	08-05-93
3	ENGR. & INSPEC.	10-27-93
4		
5		
6		
NO.	REVISIONS	DATE

DATE: 11/02/93
SCALE: NO SCALE
DRAWING BY: CLN,AF
DESIGNED BY: G:\CAD\DETAILS\EROSION\EROSION)
APPROVED BY: GWS,III

SHEET  
9  
WVWA ID# 6PHP4D