

SEE SHEET 3 FOR LEGEND



WATER SYSTEM HGL (feet) = 1,430			
SECTION	LOT NUMBER	WML (feet)	STATIC PRESSURE (psi)
1	13	1,275.8	68.3
1	14 & 15	1,271.5	60.2
1	16 & 17	1,268.0	58.7
2	1 & 2	1,480.0	56.5
2	3 & 4	1,384.0	54.8
2	5 & 6	1,287.0	53.5
2	7 & 8	1,280.5	52.4
2	9	1,200.0	51.8
2	10 & 11	1,291.5	52.5
2	12 & 12A	1,291.2	52.7
2	14 & 15	1,489.1	53.6
2	16 & 17	1,488.2	53.8
2	18 & 19	1,291.4	53.6
2	20 & 21	1,298.7	51.4
2	22 & 23	1,300.9	47.0
2	24	1,300.2	47.5
2	25 & 26	1,288.5	48.7
2	27 & 28	1,292.3	51.2
2	29 & 30	1,286.4	53.7
3	1 & 2	1,278.0	57.4
3	3 & 4	1,283.4	57.0
3	5 & 6	1,298.0	48.7
3	7	1,298.0	48.7
3	8 & 9	1,294.5	50.2
3	10 & 11	1,284.6	54.5
3	12 & 12A	1,278.3	37.3
4	1 & 2	1,271.5	60.2
4	3 & 4	1,281.4	55.7
4	5 & 6	1,283.3	55.1
4	7	1,277.4	59.4
4	8 & 9	1,287.0	61.8
4	10	1,276.0	57.0

FIRE FLOW INFORMATION IS BASED ON INFORMATION PROVIDED BY THE WESTERN VIRGINIA WATER AUTHORITY AND A WATERCAD COMPUTER SIMULATION. THIS INFORMATION HAS NOT BEEN FIELD VERIFIED.
(REQUIRED FIRE FLOW = 1,000 GPM)

NO.	DATE	DESCRIPTION
1	1/15/2020	SEE PLAN REVISION TABLE ON SHEET NO. 3
2	11/12/2021	SEE PLAN REVISION TABLE ON SHEET NO. 3
3	1/25/2022	SEE PLAN REVISION TABLE ON SHEET NO. 3
4	10/12/2022	SEE PLAN REVISION TABLE ON SHEET NO. 3

DATE: **March 10, 2020**

SCALE: **1" = 50'**

COMMISSION: **2003-374N**

SHEET **5** OF **19**