

03374ncomp2019-05-dm02.alt

WORK IN THE R/W SHALL TO BE
PERFORMED PER THE CITY OF ROANOKE
RIGHT OF WAY EXCAVATION AND
RESTORATION STANDARDS



WATER SYSTEM HGL (feet) = 1,410			
SECTION	LOT NUMBER	WM ELEV (feet)	STATIC PRESSURE (lbs)
1	13	1,275.8	58.3
1	14 & 15	1,271.6	60.2
1	16 & 17	1,268.0	61.7
2	1 & 2	1,280.0	56.5
2	3 & 4	1,284.0	54.8
2	5 & 6	1,287.0	53.5
2	7 & 8	1,289.5	52.4
2	9	1,290.9	51.8
2	10 & 11	1,291.6	51.5
2	12 & 12A	1,291.2	51.7
2	14 & 15	1,289.1	52.6
2	16 & 17	1,286.2	53.8
2	18 & 19	1,291.4	51.6
2	20 & 21	1,298.7	48.4
2	22 & 23	1,301.9	47.0
2	24	1,300.2	47.7
2	25 & 26	1,298.5	48.5
2	27 & 28	1,292.3	51.2
2	29 & 30	1,286.4	53.7
3	1 & 2	1,278.0	57.4
3	3 & 4	1,283.4	55.0
3	5 & 6	1,298.0	48.7
3	7	1,298.0	48.7
3	8 & 9	1,294.5	50.2
3	10 & 11	1,284.6	54.5
3	12 & 12A	1,278.3	57.3
4	1 & 2	1,271.5	60.2
4	3 & 4	1,281.8	55.7
4	5 & 6	1,283.3	55.1
4	7	1,278.9	57.0
4	8 & 9	1,273.4	59.4
4	10	1,267.9	61.8

FIRE FLOW INFORMATION IS BASED ON INFORMATION PROVIDED BY THE WESTERN VIRGINIA WATER AUTHORITY AND A WATERCAD COMPUTER SIMULATION. THIS INFORMATION HAS NOT BEEN FIELD VERIFIED.
(REQUIRED FIRE FLOW = 1,000 GPM)

REVISIONS		
NO.	DATE	DESCRIPTION
1	4/15/2022	SEE PLAN REVISION TABLE ON SHEET No. 3
2	11/2/2022	SEE PLAN REVISION TABLE ON SHEET No. 3
3	3/25/2022	SEE PLAN REVISION TABLE ON SHEET No. 3
4	5/12/2023	SEE PLAN REVISION TABLE ON SHEET No. 3
5		

DATE: **March 10, 2020**

SCALE: **1" = 50'**

COMMISSION NO: **2003-374N**

SHEET 5 OF 19