

GENERAL NOTES

LEGEND		
DESCRIPTION	EXISTING	PROPOSED
5' OR 10' CONTOUR LINE		
1' OR 2' CONTOUR LINE		
RIGHT-OF-WAY		
SILT FENCE		
STORM SEWER		
SANITARY SEWER		
OVERHEAD ELECTRIC		
UTILITY POLE		
LIGHT POLE		
SANITARY MANHOLE		
SIGN - SINGLE FACED		
SIGN - DOUBLE FACED		
PERMANENT UTILITY EASEMENT		
TEMPORARY CONSTRUCTION EASEMENT		
TREES, SHRUBS, BUSHES		
DETAIL CALLOUT		
DETAIL IDENTIFICATION NO.		

NOTE: SOME FEATURES IN THE LEGEND MAY NOT HAVE BEEN USED

- THE "OWNER" IS THE WESTERN VIRGINIA WATER AUTHORITY (AUTHORITY). THE TERMS "OWNER" AND "AUTHORITY" ARE USED INTERCHANGEABLY IN THE CONTRACT DOCUMENTS.
- THE CONTRACTOR SHALL NOTIFY THE AUTHORITY'S ENGINEERING COORDINATOR, MARK SINK, AT 540-537-3460 AT LEAST THREE (3) DAYS PRIOR TO CONSTRUCTION.
- A PRE-CONSTRUCTION CONFERENCE SHALL BE SCHEDULED AT LEAST ONE (1) DAY PRIOR TO ANY CONSTRUCTION.
- CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR SITE SAFETY AND FOR COMPLIANCE WITH ALL FEDERAL, STATE AND LOCAL HEALTH AND SAFETY CODES, LAWS, REGULATIONS AND ORDINANCES INCLUDING, BUT NOT LIMITED TO, THE OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA)
- CONTRACTOR SHALL FIELD VERIFY ALL SITE CONDITIONS PRIOR TO COMMENCING WORK AND SHALL NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
- ALL EXISTING UTILITIES MAY NOT BE SHOWN OR MAY NOT BE SHOWN IN THEIR EXACT LOCATION. CONTRACTOR SHALL LOCATE ALL UTILITIES AND DETERMINE ALL INVERTS PRIOR TO CONSTRUCTION TO ALLOW FOR ADJUSTMENTS DUE TO CONFLICTS WITH OTHER UTILITIES. THE CONTRACTOR SHALL COMPLY WITH THE VIRGINIA STATE WATER WORKS REGULATIONS, SECTION 12VAC5-590-1150, AND THE VIRGINIA STATE SEWAGE COLLECTION AND TREATMENT (SCAT) REGULATIONS WHERE LINES CROSS.
- THE CONTRACTOR SHALL HAVE A VALID MISS UTILITY TICKET PRIOR TO EXCAVATION. CONTACT MISS UTILITY AT 1-800-552-7001.
- PRIOR TO CONSTRUCTION, ALL APPLICABLE PERMITS FROM THE GOVERNING JURISDICTIONS AND/OR AGENCIES MUST BE OBTAINED AND A COPY KEPT ON THE PROJECT SITE. CONTRACTOR SHALL OBTAIN ALL REQUIRED PERMITS AND PAY ALL FEES OF SUCH, PRIOR TO COMMENCING WORK.
- CONTRACTOR SHALL OBTAIN REQUIRED PERMITS FROM CITY OF ROANOKE, ROANOKE COUNTY AND/OR VDOT.
- CONTRACTOR SHALL PROVIDE ANY SHORING REQUIRED TO PROTECT EXISTING FACILITIES DURING EXCAVATION FOR INSTALLATION OF PROPOSED STRUCTURES AND UTILITIES. CONTRACTOR SHALL BE RESPONSIBLE FOR SHORING DESIGN. DESIGN SHALL BE PERFORMED BY A REGISTERED PROFESSIONAL ENGINEER LICENSED TO PRACTICE IN THE COMMONWEALTH OF VIRGINIA. ALL ANTICIPATED COSTS FOR SHORING AND DESIGN SHALL BE INCLUDED IN THE CONTRACTOR'S BASE BID PRICE.
- ALL CONSTRUCTION METHODS AND MATERIALS SHALL CONFORM TO THE LATEST EDITION OF THE WESTERN VIRGINIA REGIONAL DESIGN AND CONSTRUCTION STANDARDS. (STANDARDS) AVAILABLE AT WWW.WESTERNVAVATER.ORG OR BY CONTACTING THE AUTHORITY AT 540-853-5700. THE PROJECT SHALL ALSO COMPLY WITH THE GOVERNING JURISDICTION'S STANDARDS AND OTHER AGENCY STANDARDS (E.G., VDOT, DEQ, DCR, VDH, ETC.) WHERE APPLICABLE. CONTRACTOR SHALL PROVIDE A COPY OF THE CONTRACTOR'S DESIGNATED CERTIFIED VIRGINIA RESPONSIBLE LAND DISTURBER CERTIFICATE TO THE OWNER PRIOR TO CONSTRUCTION.
- THE CONTRACTOR SHALL PROVIDE ADEQUATE MEANS OF CLEANING ALL VEHICLES AND EQUIPMENT PRIOR TO ENTERING PUBLIC STREETS. IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT THE STREETS ARE KEPT IN A CLEAN, MUD- AND DUST-FREE CONDITION AT ALL TIMES.
- CONSTRUCTION DEBRIS SHALL BE CONTAINERIZED IN ACCORDANCE WITH THE VIRGINIA LITTER CONTROL ACT. PRIOR TO COMMENCING WORK, THE CONTRACTOR'S CERTIFIED RESPONSIBLE LAND DISTURBER SHALL OBTAIN AN EROSION AND SEDIMENT CONTROL PERMIT FOR THE PROJECT FROM THE LOCAL GOVERNING JURISDICTION AND STORMWATER MANAGEMENT PERMIT FROM DCR (IF REQUIRED). ALL EROSION AND SEDIMENT CONTROL MEASURES MUST BE IN ACCORDANCE WITH THE LATEST EDITION OF THE VIRGINIA EROSION AND SEDIMENT CONTROL HANDBOOK AND SHALL BE INSTALLED PRIOR TO CONSTRUCTION. THE CONTRACTOR SHALL MAKE PROVISIONS TO PROVIDE ACCESS TO ALL PROPERTIES DURING CONSTRUCTION AND SHALL MAINTAIN SAFE ACCESSIBILITY TO FIRE HYDRANTS AT ALL TIMES.
- THE CONTRACTOR SHALL NOT EXCAVATE MORE TRENCH LENGTH THAN CAN BE RESTORED WITHIN THE SAME WORK DAY. ALL TRENCHES SHALL BE BACKFILLED OR PLATED AT THE END OF EACH WORK DAY OR WHEN THE CONTRACTOR IS NOT ON SITE.
- CONTRACTOR SHALL RESTORE ALL AREAS DISTURBED BY CONSTRUCTION; INCLUDING ACCESS AND SITE ROADWAYS, DITCHES, DRAINAGE STRUCTURES AND OTHER EXISTING FEATURES TO THEIR ORIGINAL CONDITION OR TO A CONDITION SATISFACTORY TO THE ENGINEER.
- ALL REQUIRED TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED BY THE CONTRACTOR IN ACCORDANCE WITH THE APPROVED SEDIMENT AND EROSION CONTROL PLAN.
- CONSTRUCTION CREWS MUST ALLOW FOR SOLID WASTE MANAGEMENT TO SERVICE TRASH, RECYCLING, BULK, AND BRUSH COLLECTION FOR THE ENTIRE PROJECT AREA.

- SEWER PIPE MATERIAL SHALL BE PER THE STANDARDS UNLESS OTHERWISE INDICATED ON THE PLANS.
- PROFILES SHOW SEWER LENGTH FROM MANHOLE CENTER TO MANHOLE CENTER. HOWEVER, PAYMENT SHALL BE MADE FOR LENGTH FROM INSIDE MANHOLE TO INSIDE MANHOLE.
- SEWER SLOPES ARE CALCULATED BASED ON SEWER LENGTH FROM MANHOLE CENTER TO MANHOLE CENTER. MANHOLE PENETRATION INVERTS AND SEWER SLOPES SHALL BE COORDINATED IN THE FIELD.
- CONTRACTOR SHALL BE RESPONSIBLE FOR THE STAKING AND LAYOUT OF ALL PROPOSED STRUCTURES AND IMPROVEMENTS.
- PORTIONS OF THE SANITARY SEWER TO BE REPLACED PASS UNDER EXISTING DRAINAGE SWALES. CONTRACTOR IS ENCOURAGED TO PERFORM THESE TASKS ONLY DURING DRY WEATHER TO AVOID COMPROMISING AND OBSTRUCTING EXISTING DRAINAGE PATTERNS DURING A RAINFALL EVENT.
- ALL DISTURBED AREAS SHALL BE RETURNED TO LIKE OR BETTER CONDITION WHETHER THEY ARE GRASSED, LANDSCAPED, GRAVELED OR OTHER. ANY DISTURBED PLANTINGS SHALL BE REPLACED WITH LIKE SPECIES.
- ANY FENCING DISTURBED BY CONSTRUCTION ACTIVITIES SHALL BE IMMEDIATELY REPLACED OR SUPPLEMENTED BY TEMPORARY FENCING TO MAINTAIN A SECURE SITE THROUGHOUT CONSTRUCTION. UPON COMPLETION OF CONSTRUCTION ACTIVITIES, FENCING SHALL BE RESTORED TO ORIGINAL CONDITIONS.
- A MINIMUM OF 18" SEPARATION MUST BE MAINTAINED BETWEEN UTILITIES AT ALL PIPE CROSSINGS.
- ANY TREES GREATER THAN 2" IN DIAMETER SHALL NOT BE REMOVED WITHOUT WRITTEN PERMISSION FROM THE AUTHORITY.
- THE CONTRACTOR SHALL PERFORM ALL MANHOLE CONNECTIONS. THE CORING AND BOOT INSTALLATION SHALL BE INSPECTED AND APPROVED BY AN AUTHORITY CONSTRUCTION INSPECTOR PRIOR TO ACTIVATING SEWER SERVICE. THE CONTRACTOR SHALL CONTACT THE AUTHORITY'S CONSTRUCTION INSPECTOR RESPONSIBLE FOR THE PROJECT AT LEAST ONE (1) DAY PRIOR TO INITIATING THE MANHOLE CONNECTION.
- THE CONTRACTOR SHALL SUPPLY THE AUTHORITY WITH CORRECT AS-BUILT PLANS BEFORE SUBSTANTIAL COMPLETION WILL BE GRANTED.
- HORIZONTAL DATUM IS VIRGINIA STATE PLANE COORDINATE SYSTEM SOUTH ZONE NAD 83. VERTICAL DATUM IS NAVD 88.
- FIELD CHANGES SHALL BE APPROVED BY THE AUTHORITY'S ENGINEERING DIVISION AND ENGINEER PRIOR TO SUCH CONSTRUCTION.
- ALL WORK SHALL BE CONTAINED WITHIN THE EXISTING RIGHT OF WAY AND/OR PROPOSED OR EXISTING EASEMENTS.
- ALL EXCAVATION, INCLUDING ROCK, SHALL BE UNCLASSIFIED. NO ADDITIONAL PAYMENT WILL BE MADE FOR ROCK. PER THE STANDARDS, SECTION CS-6, "ALL ROCK EXCAVATION SHALL BE PAID FOR AS AN INCIDENTAL PART OF THE ITEMS ON WHICH THE WORK IS DONE".
- ALTHOUGH SUCH WORK MAY NOT BE SPECIFICALLY SHOWN, THE CONTRACTOR SHALL FURNISH AND INSTALL ANY SUPPLEMENTAL OR MISCELLANEOUS ITEMS, APPURTENANCES AND DEVICES INCIDENTAL TO OR NECESSARY FOR A SOUND AND COMPLETELY OPERATIONAL INSTALLATION.
- EXISTING PIPING THAT IS NOT TO BE REUSED CAN BE ABANDONED IN PLACE. ABANDONED PIPES THAT HAVE CONVEYED SEWAGE SHALL BE ABANDONED IN ACCORDANCE WITH THE VIRGINIA SCAT REGULATIONS.
- THE PLANS AND SPECIFICATIONS SHALL GOVERN FOR THIS PROJECT; HOWEVER, IF THESE DOCUMENTS DO NOT COVER A PARTICULAR ITEM OR PORTION OF THE WORK, THE STANDARDS, LATEST EDITION, SHALL GOVERN.
- THE CONTRACTOR SHALL FIELD VERIFY SIZE, LOCATION, AND INVERT OF ALL SUBMANS, AND MAINS ENTERING MANHOLES AND PROVIDE THIS INFORMATION AS PART OF THE SHOP DRAWINGS SUBMITTAL.
- ACCESS TO PRIVATE, PUBLIC, AND COMMERCIAL BUSINESSES AFFECTED BY THE UTILITY CONSTRUCTION SHALL BE MAINTAINED AT ALL TIMES DURING THEIR RESPECTIVE NORMAL BUSINESS HOURS.

SHEET LIST TABLE	
SHEET NUMBER	SHEET TITLE
G-001	COVER SHEET
G-002	LEGEND, GENERAL NOTES AND ABBREVIATIONS
C-101	MUDLICK CREEK SANITARY SEWER PLAN & PROFILE
C-501	EROSION & SEDIMENT CONTROL MARRATIVE, NOTES, AND DETAILS
C-502	SANITARY SEWER DETAILS

TABLE OF ABBREVIATIONS (NOT ALL ABBREVIATIONS MAY HAVE BEEN USED)							
AASHTO	AMERICAN ASSOCIATION OF STATE HIGHWAY AND TRANSPORTATION OFFICIALS	CFM	CUBIC FEET PER MINUTE	FT	FOOT OR FEET	MON	MONUMENT
ABS	PLASTIC PIPE	CI	CURB INLET	GAL	GALLON	N	NORTH
AC	ACRE	CIP	CAST IRON PIPE	GPM	GALLONS PER MINUTE	NAVAIDS	NAVIGATIONAL AIDS
ACCM	ASPHALT COATED CORRUGATED METAL	CL	CLASS OR CENTERLINE	GRD	GROUND OR GRADE	NIC	NOT IN CONTRACT
AFF	ABOVE FINISHED FLOOR	CMP	CORRUGATED METAL PIPE	GV	GATE VALVE	NOTAM	NOTICE TO AIRMEN
ALT	ALTERNATE	CO	CLEANOUT	HDPE	HIGH DENSITY POLYETHYLENE PIPE	O/S	OFFSET
ASZ	AIRPORT SAFETY ZONE	CONC	CONCRETE	HORIZ	HORIZONTAL	OFA	OBJECT FREE AREA
APPROX	APPROXIMATE	CR	COUNTRY ROAD	HP	HIGH POINT OR HORSE POWER	OFZ	OBSTACLE FREE ZONE
ASPH	ASPHALT	CSP	CORRUGATED STEEL PIPE	HPS	HIGH PRESSURE SODIUM	OAR	OWNER'S AUTHORIZED REPRESENTATIVE
ATCT	AIR TRAFFIC CONTROL TOWER	CTR	CENTER	HR	HAND RAIL OR HOUR	PL	PROPERTY LINE
AWG	AMERICAN WIRE GAUGE	CULV	CULVERT	HT	HEIGHT	PC	POINT OF CURVATURE
BL	BASELINE	CV	CHECK VALVE	HW	HEADWALL	PE	PERMANENT UTILITY EASEMENT
BB	BOTTOM OF BANK OR BERM	CY	CUBIC YARD	HYD	HYDRANT	PERF	PERFORATED
BC	BOTTOM OF CURB	D	DRAIN	IN	INCH(ES)	PERP	PERPENDICULAR
BFE	BASEMENT FLOOR ELEVATION	DI	DROP INLET	IP(F)	IRON PIPE (FOUND)	PP	POWER POLE, POWER PANEL
BLDG	BUILDING	DIA	DIAMETER	JB	JUNCTION BOX	PPM	PARTS PER MILLION
BM	BENCHMARK	DIP	DUCTILE IRON PIPE	LAT	LATITUDE	PRC	POINT OF REVERSE CURVATURE
BOT	BOTTOM	DWG	DRAWING	LB	POUND	PSF	POUNDS PER SQUARE FOOT
BRL	BUILDING RESTRICTION LINE	E	EAST	LF	LINEAR FOOT OR LINEAR FEET	PSI	POUNDS PER SQUARE INCH
BSMT	BASEMENT	EA	EACH	LONG	LONGITUDE	PT	POINT OR POINT OF TANGENCY
BVC	BEGINNING OF VERTICAL CURVE	EJ	EXPANSION JOINT	LP	LAMP POST, LIGHT POLE, LIGHT PANEL OR LOW POINT	PVC	POINT OF VERTICAL CURVATURE OR POLYVINYL CHLORIDE
BW	BOTTOM OF WALL	ELEC	ELECTRIC	LT	LEFT	PVI	POINT OF VERTICAL INTERSECTION
C	CHORD	ELEV	ELEVATION	LT	LEFT	PVT	POINT OF VERTICAL TANGENCY
CAP	CORRUGATED ALUMINUM PIPE	EOP	EDGE OF PAVEMENT	MFR	MANUFACTURER	PWR	POWER
CB	CATCH BASIN	FD	FLOOR DRAIN	MH	MANHOLE	R	RADIUS
CF	CUBIC FOOT OR CUBIC FEET	FDN	FOUNDATION	MIN	MINIMUM	RAD	RADIAL
		FFE	FINISHED FLOOR ELEVATION	MISC	MISCELLANEOUS		
						RCCP	REINFORCED CONCRETE CULVERT PIPE
						RCP	REINFORCED CONCRETE PIPE
						RD	ROOF DRAIN
						REINF	REINFORCING
						REQD	REQUIRED
						ROW	RIGHT-OF-WAY
						ROW W/A	RIGHT-OF-WAY WITH ACCESS
						ROW WO/A	RIGHT-OF-WAY WITHOUT ACCESS
						RPM	REVOLUTIONS PER MINUTE
						RR	RAILROAD
						RSA	RUNWAY SAFETY AREA
						RT	RIGHT
						RW	RETAINING WALL
						RWY, R/W	RUNWAY
						S	SOUTH
						SCH	SCHEDULE
						SF	SQUARE FOOT OR SQUARE FEET
						SH	STATE HIGHWAY
						SHT	SHEET
						SMH	SANITARY MANHOLE
						SPECS	SPECIFICATIONS
						SS	SANITARY SEWER
						STA	STATION OR STATIONARY
						STMH	STORM MANHOLE
						STY	STORY
						SY	SQUARE YARD
						TAN	TANGENT
						TC	TOP OF CURB
						TE	TEMPORARY CONSTRUCTION EASEMENT
						TEL	TELEPHONE
						TEMP	TEMPORARY
						TF	TOP OF FRAME
						TRANS	TRANSFORMER OR TRANSVERSE
						TSA	TAXIWAY SAFETY AREA
						TV	TELEVISION
						TWY, T/W	TAXIWAY
						TYP	TYPICAL
						UD, U/D	UNDERDRAIN
						U(ND)G	UNDERGROUND
						UTIL	UTILITY
						VC	VERTICAL CURVE
						VCP	VITRIFIED CLAY PIPE
						VERT	VERTICAL
						VOL	VOLUME
						W	WEST
						W/	WITH
						WF	WOOD FRAME
						W/O	WITHOUT
						WW	WING WALL
						WWF	WELDED WIRE FABRIC OR WOVEN WIRE FABRIC



IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, ARCHITECT, LANDSCAPE ARCHITECT OR LAND SURVEYOR TO ALTER AN ITEM IN ANY WAY. IF AN ITEM BEARING THE SEAL OF A LICENSED PROFESSIONAL IS ALTERED, THE ALTERING ENGINEER, ARCHITECT, LANDSCAPE ARCHITECT OR LAND SURVEYOR SHALL STAMP THE DOCUMENT AND INCLUDE THE NOTATION "ALTERED BY" FOLLOWED BY THEIR SIGNATURE, THE DATE OF SUCH ALTERATION, AND A SPECIFIC DESCRIPTION OF THE ALTERATION.

WESTERN VIRGINIA WATER AUTHORITY
 OLD ROANOKE RIVER INTERCEPTOR IMPROVEMENTS - PHASE 3
 MUDLICK CREEK INTERCEPTOR EXTENSION

No.	Submittal / Revision	App'd.	By	Date
1	BID ISSUE	DBH	RAS	11/08/19

LEGEND, GENERAL NOTES AND ABBREVIATIONS

Designed By:	Drawn By:	Checked By:
EES	RAS	DBH
Issue Date:	Project No:	Scale:
NOV 8, 2019	35105	NONE

Drawing No.:
G-002

File: V:\PROJECTS\ANY\5\35105\CADD\CADD\G-002_35105.DWG
 Saved: 11/7/2019 12:42:12 PM Plotted: 11/7/2019 9:51:52 AM Current User: Squirres_Alan Last Saved By: 5548