





36" x 48" DOUBLE DOOR GUTTER-FRAME H2O RATED ALUM. ACCESS HATCH (E-Z SET GDH-3648)



NOTES:

1. CLEAR FLOW VAULT SHIPPED ASSEMBLED WEIGHING APPROX. 16,000 LBS.
2. 8" WILKINS 310DAL SINGLE CHECK DETECTOR ASSEMBLY w/ OS&Y GATE VALVE
3. 2" METER SUPPLIED TO CLEAR FLOW BY THE WESTERN VA WATER AUTHORITY

DESIGN		
DRAWN	STEVEN L. GORDON	
REVISIONS		DATE
DBL. DOOR HATCH; 12" SHORTER		11/15/07
BYPASS SIDE		12/08/08
WILKINS 310DAL SINGLE CHECK		1/05/11

CLEAR FLOW
By AMERICAST



210 STONE SPRING ROAD
HARRISONBURG, VA 22801
(540) 434 - 2130

REF. NO. P-41543-S

ROANOKE COUNTY, VIRGINIA
NORFOLK SOUTHERN
TBT FACILITY
8" DC VAULT w/
2" DOMESTIC METER
ANDERZACK-PITZEN CORP.