

DESCRIPTION of FIELD REVISION No.2

The Contractor uncovered an 8" sanitary sewer lateral originating at the Independent Living facility located adjacent to and above the project site. The lateral connects to the Sanitary Sewer Manhole labeled "Ex4" on the plans, and was not known to exist prior to its discovery.

This field revision proposes to install a new sanitary sewer manhole on the existing 8" sewer main above structure "Ex4." This proposed structure, labeled "10" on the Field Revision plan, will allow for the realignment of the 8" lateral.

The location for Manhole "10" is taken from prior development plans for the site, and the structure is the upstream end of a larger sanitary sewer relocation to allow for a building pad on the end of the site nearest Van Winkle Road. It is anticipated that this relocation will occur with the next phase of development, and that Manhole "10" will serve the future development effort.

The following plan sheet is included in this submission:

- FIELD REVISION No.2 PLAN & PROFILE sheet (1 of 1; ref. approved plan sheet 5)

APPROVED

By Adrian Gilbert at 4:11 pm, Mar 23, 2016