

- ALL WATER FACILITIES SHALL BE INSTALLED ACCORDING TO THE WESTERN VIRGINIA WATER AUTHORITY (WVWA) DESIGN AND CONSTRUCTION STANDARDS (LATEST REVISION).
- THE CONTRACTOR SHALL FLUSH AND DISINFECT IN ACCORDANCE WITH AWWA SPECIFICATION C651. LATEST REVISION. CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING AND UNCOVERING VALVE VAULTS AFTER PAVING AND ADJUSTMENT TO FINAL GRADE IF NECESSARY.
- 4. A MINIMUM COVER OF 3 FEET IS REQUIRED OVER PROPOSED LINES, EXCEPT WHERE SHOWN. ALL CONNECTIONS TO EXISTING WATER MAINS SHALL BE COORDINATED WITH THE WVWA.
- 6. ANY FIRE HYDRANT TAKEN OUT OF SERVICE AND NOT REUSED SHALL BE PROPERTY OF THE WVWA. THE INSPECTOR SHALL CONTACT FIELD OPERATIONS AND COORDINATE FIELD OPERATIONS PICK UP OF THE HYDRANT.
- 7. CONTRACTOR SHALL CONFIRM EXISTING SERVICES/STRUCTURES MARKED FOR DEMOLITION ARE INACTIVE PRIOR TO DEMOLITION. OWNER WILL ASSIST CONTRACTOR WITH NOTIFICATION.
- 8. CONTRACTOR SHALL PERFORM EXPLORATORY EXCAVATIONS AT UTILITY CROSSINGS TO VERIFY DEPTH PRIOR TO CONSTRUCTION.
- 1. ALL DRIVEWAYS, SIDEWALK, CURBING, FENCING, CULVERTS & MAILBOXES MUST BE RESTORED TO EXISTING CONDITIONS AFTER CONSTRUCTION IS COMPLETED. ANY CHANGES TO EXISTING CONDITIONS MUST BE APPROVED BY WVWA.
- CONTRACTOR SHALL PROTECT SHRUBS & LANDSCAPING DURING CONSTRUCTION. CONTRACTOR SHALL RELOCATE/REESTABLISH SHRUBS AS NEEDED.
- CONTRACTOR SHALL PROTECT CURBING FROM DAMAGE. CONTRACTOR SHALL PROTECT PROPERTY PINS, PROPERTY PINS SHALL NOT BE DISTURBED DURING CONSTRUCTION.
- CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING POLE/GUY WIRE PROTECTION AS NEEDED FOR CONSTRUCTION. ALL EXISTING UTILITIES MAY NOT BE SHOWN IN THE EXACT LOCATION.
- 7. ALL PAVEMENT CUTS SHALL BE SAW CUT AND EDGES TACK COATED PRIOR TO PAVING.

VICE TE 30 SER\ 11, SUI 2401 5700 JEFFREY W. ROGERS 07/31/2020 \triangleleft Designed: N/A Drawn: DRJ Checked: DRJ, MRD Approved: JWR Date: 07/29/2020 Project: WCIP-133 Sheet 4 of 7