





CONTROL LEGEND

ILF	IN-LINE FUSE
O	OPEN
C	CLOSED
N	NEUTRAL
CR	CONTROL RELAY
	NORMALLY OPEN CONTACT
	NORMALLY CLOSED CONTACT
	CONDUCTOR TAP
R	RED
W	WHITE
B	BLACK
CRT	CIRCUIT
	GROUND

NOTES:

1. PROVIDE A LABEL FOR EACH PIECE OF EQUIPMENT INDICATED. LABELS SHALL BE ENGRAVED LAMINATED PLASTIC WITH 1/4" HIGH LETTERS AND SHALL BE ATTACHED WITH 2-SHEET METAL SCREWS OR POP RIVETS TO THE COVER OF THE EQUIPMENT.
2. ALL CONTROL COMPONENTS SHALL HAVE NEMA-1 ENCLOSURES
3. PROVIDE WIRING DIAGRAM AND FRONT ELEVATION OF CONTROL EQUIPMENT TO ENGINEER FOR APPROVAL BEFORE INSTALLATION.
4. CONTROL WIRING MAY BE 14 AWG AND MAY BE EXPOSED IN CONTROL CABINET. ALL POWER WIRING SHALL BE IN CONDUIT INSIDE CONTROL CABINET.
5. PROVIDE INLINE FUSE HOLDERS AND FUSES SIZED FOR CONTROL EQUIPMENT AS RECOMMENDED BY MANUFACTURER.
6. SELECTOR SWITCHES SHALL BE SQUARE D GG-123 OR EQUAL.
7. GROUND ALL CONTROL DEVICE ENCLOSURES TO SYSTEM GROUND WITH NO. 14 AWG COPPER.
8. PROVIDE GROMMETS IN ALL OPENINGS IN WIRE WAY WHERE CONDUIT IS NOT USED.
9. AS BUILT CONTROL WIRING DIAGRAM SHALL BE ATTACHED TO INSIDE OF DOOR ON CONTROL CABINET.

