

AEP NOTE:

1. A 50' TRIGGER DISTANCE AND 35' MINIMUM APPROACH DISTANCE SHALL BE MAINTAINED FROM THE EXISTING FUNK-CLOVERDALE 765 KV AEP-APCO POWER LINES FOR ALL EQUIPMENT AT ALL TIMES.
2. A 50' TRIGGER DISTANCE AND 45' MINIMUM APPROACH DISTANCE SHALL BE MAINTAINED FROM THE EXISTING FUNK-CLOVERDALE 765 KV AEP-APCO POWER LINES FOR ALL CRANES AT ALL TIMES.
3. D.C. SHALL ENSURE THERE IS NO LAND DISTURBANCE WITHIN THE 45' BUFFER AROUND AEP STRUCTURE 88-142.

