


KEYNOTES:

- 21 NOT USED
- 22 NEW FIRE HYDRANT, 6" VALVE, 6" PIPE AND 8"x6" TEE (REMOVE EXISTING HYDRANT, VALVE, ETC...)
- 23 NOT USED
- 24 NOT USED
- 25 NOT USED
- 26 REMOVE EXISTING WATERLINE WHEN IN CONFLICT WITH CONSTRUCTION OF SANITARY SEWER (FOR OPEN-CUT ALTERNATE). ABANDON EXISTING WATERLINE IN PLACE WHERE NO CONFLICT OCCURS WITH NEW CONSTRUCTION. PROVIDE APPROPRIATE PLUGS TO WATERLINE ABANDONED IN PLACE.
- 27 NOT USED
- 28 NOT USED
- 29 NOT USED
- 30 NOT USED
- 31 NOT USED
- 32 NOT USED
- 33 LIMITS OF PAVEMENT PLANING AND OVERLAY. REFER TO TYPICAL SECTION-PAVEMENT OVERLAY ON SHEET 6
- 34 EXISTING CURB AND GUTTER TO REMAIN.

KEYNOTES:

- 1 NOT USED
- 2 NOT USED
- 3 NOT USED
- 4 NEW 8" WATERLINE. REFER TO SHEET 14 FOR PROFILE AND ADDITIONAL INFORMATION.
- 5 NOT USED
- 6 NOT USED
- 7 NOT USED
- 8 NOT USED
- 9 8"x6" REDUCER, 6"x6" TAPPING SLEEVE AND VALVE.
- 10 NOT USED
- 11 NOT USED
- 12 NOT USED
- 13 NOT USED
- 14 NOT USED
- 15 6" RESTRAINED PLUG(S)
- 16 NOT USED
- 17 CONNECT TO EXISTING 6" & 2" WATERLINE AS SHOWN. CONTRACTOR SHALL VERIFY SIZE AND LOCATION OF EXISTING WATERLINE IN THE INTERSECTION OF BLAIR ST. AND LEE AVENUE AND THE SIZE AND LOCATION OF THE WATERLINE IN SPRUCE STREET.
- 18 CONNECT WATER SERVICE TO NEW PIPE
- 19 NOT USED
- 20 NOT USED

RECORD DRAWINGS
11-21-02



Revisions	Date
1. ADDENDUM #1	9/7/02
2. RECORD DRAWINGS	11/21/02

Issue Date:	AUG. 19, 2001
Drawn By:	JPR
Designed By:	JPR
Checked By:	SWH
Date:	AUG. 17, 2001

Matthew & Craig
CONSULTING ENGINEERS • SURVEYORS
301 FIRST STREET, S.W.
ROANOKE, VIRGINIA 24016
TEL (800) 345-7601
FAX (540) 345-7601

DOWNTOWN IMPROVEMENTS
PLAN - LEE AVENUE
IMPROVEMENTS
TOWN OF VINTON, VIRGINIA

Vertical Scale:	N/A
Horizontal Scale:	1"=20'
Commission Number:	19558
Sheet No.:	7