

Hunting Hills Shopping Center Job Site (Site Plan)

Water Line

Contractor:

E.C. Pace & Co.

Forman = Jeff

12-22-88 Started laying Pipe

4-3-89 Completed laying Pipe

4-10-89 Pressure Tested Line = O.K.

Water Samples

4-11-89 Pass

4-12-89 Pass

Location of sketch #1 on page 25

Location of sketch #2 on page 27

Location of sketch #3 on page 29

Location of sketch #4 on page 31

Location of sketch #5 on page 33

Location of sketch #6 on page 35

Location of sketch #7 on page 37

Total Pipe

New 10" main 155'

New 8" main 2,720'

