

CITY OF ROANOKE, VA
UTILITY LINE SERVICES
3447 HOLLINS ROAD, N.E.
ROANOKE, VIRGINIA 24012

TH322
Cad#0673
10/10/02
10/14/02

LOG REPORT

10-04-2002

JOB # :1
DATE :10/04/02
OPERATOR :B OVERSTREET
TAPE # :
TAPE START :
TAPE STOP :
LOCATION :WALLACE AVE NE
BLOCK # :1600

PIPE INFORMATION

MANHOLE #:1
ADDRESS :WALLACE AVE
LOT 13
MANHOLE #:2
ADDRESS :WALLACE AVE
LOT 16
FLOW :WITH

AGM
SECTION LENGTH:126.3
GRADE :Good
MH CONDITION :GOOD
MH DEPTH # 1 :5'0"
MH DEPTH # 2 :4'7"
PIPE CONDITION:Good
TYPE OF JOINT :SLIP

PIPE TYPE:PVC
PIPE SIZE:8"

— SDR 35

FOOTAGE:

FAULT OR COMMENTS:

30.7 Ft

Right
Left "Y" LATERAL lot 14
Q-1 AND 2

70.0 Ft

Right "Y" LATERAL lot 15
Q-1 AND 2

109.3 Ft

Right "Y" LATERAL lot 16
Q-1 AND 2

126.3 Ft

END OF SECTION
TV FOR INSPECTION OF
NEW MAIN.MAIN O.K.
ONE LAT.INTO M.H.#1

✓

lat. plus

0+95.6

0+56.3

0+17

2