

CITY OF ROANOKE, VA  
UTILITY LINE SERVICES  
3447 HOLLINS ROAD, N.E.  
ROANOKE, VIRGINIA 24012

LOG REPORT

10-04-2002

JOB # :2  
DATE :10/04/02  
OPERATOR :B OVERSTREET  
TAPE # :  
TAPE START:  
TAPE STOP :  
LOCATION :WALLACE AVE NE  
BLOCK # :1600

PIPE INFORMATION

MANHOLE #:2  
ADDRESS :WALLACE AVE  
LOT 16  
MANHOLE #:3  
ADDRESS :WALLACE AVE  
BEHIND LOT 21  
FLOW :WITH

AGM  
SECTION LENGTH:240.8'  
GRADE :Good  
MH CONDITION :GOOD  
MH DEPTH # 2 :4'7"  
MH DEPTH # 3 :12'9"  
PIPE CONDITION:Good  
TYPE OF JOINT :SLIP  
PIPE TYPE:PVC -SDR 35  
PIPE SIZE:8"

FOOTAGE:

FAULT OR COMMENTS:

|        |          |                                                              |        |
|--------|----------|--------------------------------------------------------------|--------|
| 2+09.2 | 31.6 Ft  | Right Side "Y" LATERAL Q-1 AND 2                             | lot 17 |
| 1+70.2 | 70.6 Ft  | Right "Y" LATERAL Q-1 AND 2                                  | 18     |
| 1+31.1 | 109.7 Ft | Right "Y" LATERAL Q-1 AND 2                                  | 19     |
| 0+91.8 | 149.0 Ft | Right "Y" LATERAL Q-1 AND 2                                  | 20     |
| 0+52.7 | 188.1 Ft | Right "Y" LATERAL Q-1 AND 2                                  | 21     |
| 0      | 240.8 Ft | END OF SECTION<br>TV FOR INSPECTION OF<br>NEW MAIN.MAIN O.K. |        |