

CITY OF ROANOKE, VA
UTILITY LINE SERVICES
3447 HOLLINS ROAD, N.E.
ROANOKE, VIRGINIA 24012

LOG REPORT

10-04-2002

JOB # :3
DATE :10/04/02
OPERATOR :B OVERSTREET
TAPE # :
TAPE START:
TAPE STOP :
LOCATION :WALLACE AVE NE
BLOCK # :1600

PIPE INFORMATION

MANHOLE #:3
ADDRESS :WALLACE AVE
BEHIND LOT 21
MANHOLE #:4
ADDRESS :WALLACE AVE
BEHIND LOT 21
FLOW :WITH

AGM :
SECTION LENGTH: 46.3'
GRADE : Good
MH CONDITION :GOOD
MH DEPTH # 3 :12'9"
MH DEPTH # 4 :5'8"
PIPE CONDITION: Good
TYPE OF JOINT :SLIP

PIPE TYPE:PVC SDR 35
PIPE SIZE:8"

FOOTAGE:

46.3 Ft

FAULT OR COMMENTS:

END OF SECTION
TV FOR INSPECTION OF
NEW MAIN.MAIN O.K.