

Windsor Place Phase II
Water Line 8" section 2
Contractor: J.P. Turner (two)

Start Date: Completed Date:

6"x8" reducer +42.5

TEE #1 = +358'

TEE #1 to 8" Valve 4.5

TEE TO F.H. 14'

TEE #2 = +399'

TEE #2 to 6"x8" Valve = 4.5

TEE #2 to Plug = 40'

8" Valve = +403' = Valve to Valve

Blow off valve = +459'

From Valve to Blow off 56' of 8"

Air Tested Water Line = 7-14-89

TEST O.K. 150 P.S.I. For 2 hours

Took water sample #1 = 7-17-89 10:20 AM

Took water sample #2 = 7-18-89 10:00 AM

Water Samples = 7-24-89 GOOD

