



- Notes:
- TANK SHALL BE IN ACCORDANCE WITH AWWA D100.
 - STEEL CONSTRUCTION SHALL CONFORM TO APPLICABLE PROVISIONS OF THE AISC CODE OF STANDARD PRACTICE FOR STEEL BUILDINGS AND BRIDGES; THE AISC SPECIFICATIONS FOR THE DESIGN, FABRICATION, AND ERECTION OF STRUCTURAL STEEL FOR BUILDINGS; AND THE AWS CODE FOR WELDING IN BUILDING CONSTRUCTION.
 - WELDING SHALL BE PERFORMED BY WELDERS QUALIFIED IN ACCORDANCE WITH THE REQUIREMENTS OF THE AWS CODE.
 - ELECTRODES SHALL BE E6010.
 - STRUCTURAL BOLTS SHALL BE A325.
 - ALL TANK ACCESSORIES TO BE FIELD LOCATED BY OWNER'S REPRESENTATIVE.
 - EXACT LOCATION OF INLET, OUTLET, DRAIN AND OVERFLOW TO BE DETERMINED DURING FIELD CONSTRUCTION.
 - WATER LINES TO BE TIED TO EXISTING WATER LINES

REV:	DESCRIPTION:	BY:	DATE:
STATUS:	AS BUILT		
AYERS Engineering, LLC P.O. Box 923, Bluefield, VA 24605 www.AyersEngineering.com			
TANK SUPPLIER:	EASTERN TANK 145 KRIT ROAD PRINCETON, WV 24739		
CONTRACTOR:			
SITE:	EAGLE ROCK TANK EAGLE ROCK, VA		
TITLE:	TANK LAYOUT		
SCALE AT A1:	DATE:	DRAWN:	CHECKED:
NTS	12/06/21	BA	BA
PROJECT NO:	DRAWING NO:	REVISION:	
21041	T1	0	