

LOCATION

CHAPEL FOREST PUMPING STATION
3410 West Ridge Rd., S. W.

UNIT NO.	PUMP NO. 1	PUMP NO. 2	PUMP NO. 3
Make	Worthington 1½ U1	Worthington 1½ U1	Worthington 1½ LLRIO
G.P.M.	40	40	100
Serial No.	1542617	1541670	A131571
Size	2 x 2	2 x 2	3"S x 2"D
Suct. Pres.	-35	-35	-35
Disc. Pres.	100	100	100
T.D.H.	145	145	145?
Storage	Pressure Tank	Pressure Tank	Pressure Tank
Make Motor	Wagner	Westinghouse	Westinghouse
Serial No.			319B314689
H.P.	5	5	10
Voltage	220	220	220/440
Amp. F.L.	23	23	Max. 40
Amp. Fuse	70 Breaker	70 Breaker	20 Breaker
Phase	1	1	3
R.P.M.	3500	3485	1745
Control	Automatic	Automatic	Automatic
In-C Line	Underground	Underground	Underground
Elev. Pump	Approx. 1475'		
Max.Elev.Serv.			
Storage Elev.			
Purchased			

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE
Mercoïd Control						

REMARKS:

Impeller Dia. 9-3/4"