

- C. The entire interior of the storage tank shall be cleaned and sandblasted in accordance with Section 5 A. and Section 9.
- D. The total exterior of the storage tank shall be cleaned and painted in accordance with Section 5 B and Section 9.
- E. The tanks shall be painted in accordance with AWWA D 102 and as hereinafter specified. The proposed paint system shall be on the latest approval list of the Virginia Department of Health and approved by EPA. The Contractor shall furnish the "Affidavit of Compliance" as required by AWWA D 102. In addition, the publications listed in Section 3, as References, form a part of these specifications.
- F. Tank will be drained by Western Virginia Water Authority (Al White @ 540/853-2595). Notify Al White at least one week before starting work so tank may be properly drained.

SECTION 2. GENERAL:

- A. Within ten (10) calendar days after receiving an executed contract, submit the following:
 - 1. Submit a detailed, site-specific lead abatement plan. If the waste is determined to be hazardous by TCLP analysis, the hazardous waste management details must be addressed, including the name and location of the facility to receive waste. Abatement cannot commence until the abatement plan has been received and accepted by the Western Virginia Water Authority.
 - 2. Copy of the Contractor's written respiratory protection plan, confined space entry plan and fall protection plan.
 - 3. Complete list of materials proposed to be furnished and applied under this contract, and paint manufacturer's certification that primer and finish coats are compatible.
 - 4. Manufacturer's specifications and other data required demonstrating compliance with the specified requirements.
- B. In the event of damage, immediately make all repairs and replacement necessary to the approval of the Authority and at no additional cost to the Authority.
- C. No paint shall be applied when the surrounding air temperature, as measured in the shade, is below 50°F. No paint shall be applied when the temperature of the surface to be painted is below 35°F or less than 5°F above the dewpoint.
- D. The Contractor shall exercise particular care in allowing sufficient drying time between coats of paint, in controlling temperatures during drying and in following all other requirements of the paint manufacturer.

Project: Eugene Drive Tank Painting

Lead Abatement, Cleaning and
Painting Specification