

LOCATION

HOLLINS PUMPING STATION
7420 Plantation Road, N. E.

UNIT NO.	PUMP NO. 1	PUMP NO. 2	PUMP NO.
Make	Worthington 4L3	Worthington 4L3	
G.P.M.	695	695	
Serial No.	1405469	1405470	
Size	4"S 6"D	4"S 6"D	
Suct. Pres.	40	40	
Disc. Pres.	75 plus	75 plus	
T.D.H.	175	175	
Storage	Tank	Tank	
Make Motor	Gen. Elec.	Gen. Elec.	
Serial No.	WH6955907	WH6955905	
H.P.	50	50	
Voltage	220/440	220/440	
Amp. F.L.	120/60	120/60	
Amp. Fuse	200 Amp	200 Amp	
Phase	3	3	
R.P.M.	1765	1765	
Control	Westinghouse starter	Westinghouse starter	
In-C Line	Overhead	Overhead	
Elev. Pump	Approx. 1050'		
Max.Elev.Serv.			
Storage Elev.			
Purchased			

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE

REMARKS: