



-
- SECTION**
SCALE 1" = 10'-0"
- ELEVATION**
SCALE 1" = 10'-0"
- Labels and Callouts:**
- FLUORIDE TANK W/ SECONDARY CONTAINMENT 6000 GALLON 125' HIGH
 - FLUORIDE DAY TANK 200 GALLON 41"x52"
 - TRANSFER PUMP WITH BYPASS
 - 2" VENT THRU ROOF
 - VALVE
 - 3/4" DOMESTIC FEED FROM OVERHEAD
 - 2" FILL & VENT LINES MIN. 2% SLOPE
 - CMU WALL TO ROOF AND SEALED TO BE INSTALLED AFTER PLACEMENT OF TANKS
 - RPZ MOUNTED ON WALL
 - 3/4" FLUORIDATED WATER
 - 1310
 - FILL PORT
 - LOADING DOCK AREA
 - 12" TEE W/ WATER METER COVER TYP. 11.5" CLEAR OPENING & 20" DIA.
 - 2" POTABLE WATER SUPPLY
 - 42" FILTERED
 - 12" TEE W/ OUTSIDE LEG PLUGGED
 - 2" TRANSFER LINE
 - 12" TEE W/ OUTSIDE LEG PLUGGED
 - LIQUID LEVEL CONTROLLER
 - 18"x22" ROUND BOTTOM COLLECTOIN TROUGHS(TYP)
 - 4"x4" SQUARE DISTRIBUTION TROUGHS (TYP)
 - 24" WASTE LINE
 - 24" WASTE PIPE INVERT THRU BASIN WALL @ 1315.0
 - 1319
 - 1318
 - 1316.167
 - 1315
 - 1310
 - 11.25
 - RPZ MOUNTED ON WALL
 - 12" TEE W/ WATER METER COVER
 - 42" FILTERED
 - 12" PVC
 - 12" TEE W/ OUTSIDE LEG PLUGGED
 - 3/4" FLUORIDATED WATER
 - LIQUID LEVEL CONTROLLER
 - PIPE INV. THRU WALL @ 1309.07
 - LINK-SEAL
 - 18"x22" ROUND BOTTOM COLLECTOIN TROUGHS(TYP)
 - 30" BUTTERFLY VALVE
 - 1249.5
 - 1305

