



WASTE LINE PROFILE
 SCALE VERT 1" = 10'-0"
 HORIZ 1" = 40'-0"

NOTES

1. ALL WASTE PIPING AND FITTINGS TO BE CLASS 52 DUCTILE IRON EXCEPT FOR WATER TREATMENT PLANT PIPING
2. SEE SHEET T3 FOR PIPING IN GRANULAR ACTIVATED CARBON (GAC) CONTACTOR
3. COORDINATE WITH TANK INSTALLATION FOR CONNECTIONS TO SLUDGE TANKS
4. ALL EXTERIOR VENTS SHALL BE PROPERLY SCREENED



**ROANOKE COUNTY
 WATER TREATMENT
 FACILITY**



WASTE LINE PROFILE

DESIGN ENGINEER
 CLIFFORD D. CRAIG

COMMISSION NUMBER
 1913

RCUD NUMBER
 WTF-1

DATE
 12 SEPT. 1994

T15