





NOTES:

1. CLEAR FLOW VAULT SHIPPED ASSEMBLED WEIGHING APPROX. 16,000 LBS.
2. 6" WILKINS 310DAL SINGLE CHECK DETECTOR ASSEMBLY w/OS&Y GATE VALVE

DESIGN	STEVEN L. GORDON	12/08/08
DRAWN	REVISIONS	DATE
TAP DOMESTIC OFF FIRE LINE	1/25/11	
SENSUS OWN & IPERL METERS	3/19/12	
RECESSED RADIO READ IN HATCH	9/28/12	
CLEAR FLOW By CP&P CONCRETE PIPE & PRECAST, LLC 210 STONE SPRING ROAD HARRISONBURG, VA 22801 (540) 434 - 6979		
REF. NO. P-85140-S		ROANOKE COUNTY, VIRGINIA 903 JEFFERSON ST. CARILLION BLDG 6" DETECTOR CHECK VAULT
* PRINTOUT NOT TO ANY SCALE *		ROANOKE SPRINKLER

903 Jefferson St
3014