



HYDRANT 20553  
85 PSI STATIC  
52 PSI RESIDUAL  
1186 GPM FLOW  
INFORMATION BY WESTERN VIRGINIA  
WATER AUTHORITY

SITE PLAN

1" = 50'

*Magic City Sprinkler, Inc.*

1601 GRANBY STREET N.E. ROANOKE, VIRGINIA 24012 (540)345-9818

American Health Care  
Roanoke, Virginia

Site Detail Plan

Drawn by: Bob W	Permit #	Insp. Tel. #
Checked by:	File name:	Job no.
Scale: 1/8"=1'-0" UNO	Date: 8-25-16	Sheet 1 of 1