

CITY OF ROANOKE, VA
UTILITY LINE SERVICES
3447 HOLLINS ROAD, N.E.
ROANOKE, VIRGINIA 24012

T#443
Pg.1

LOG REPORT
02-22-2000

JOB # :1
DATE :2/22/00
OPERATOR :B OVERSTREET
TAPE # :117
TAPE START:05630
TAPE STOP :10455
LOCATION :BARTON ST SE
BLOCK # :1600

PIPE INFORMATION

MANHOLE #:1 (3) *according to plans*

ADDRESS :1607 BARTON ST

MANHOLE #:2 (2)

ADDRESS :BARTON ST AND
RIVERDALE RD

FLOW :WITH

AGM

SECTION LENGTH:249'

GRADE :Good

MH CONDITION :GOOD

MH DEPTH # 1 :11'5" — lateral out of M.H. #1

MH DEPTH # 2 :6'0"

PIPE CONDITION:Good

TYPE OF JOINT :SLIP

PIPE TYPE:PVC

PIPE SIZE:8"

M#3

2+48

D=11.41'

M#2

0+53

D=6.0'

M#1

2+76

D=14.58'

Lat. plus FOOTAGE:

2+10.1 39.1 Ft

1+51.2 98.1 Ft

Ø 249.3 Ft

FAULT OR COMMENTS:

"Y" LATERAL
Q-1 AND 2

"Y" LATERAL
Q-1 AND 2

END OF SECTION
TV FOR INSPECTION
OF NEW MAIN.

249.3
- 39.1
210.2

249.3
- 98.1
151.2