

CITY OF ROANOKE, VA
UTILITY LINE SERVICES
3447 HOLLINS ROAD, N.E.
ROANOKE, VIRGINIA 24012

✓
Pg. 2

LOG REPORT
02-22-2000

JOB # :2
DATE :2/22/00
OPERATOR :B OVERSTREET
TAPE # :117
TAPE START:10455
TAPE STOP :10650
LOCATION :BARTON ST SE
BLOCK # :1600

PIPE INFORMATION

MANHOLE #:2 (2)
ADDRESS :BARTON ST AND
RIVERDALE RD
MANHOLE #:~~3 (1)~~ *according to plan*
ADDRESS :BARTON ST AND
RIVERDALE RD
FLOW :WITH

AGM :
SECTION LENGTH: 53'
GRADE :Good
MH CONDITION :GOOD
MH DEPTH # 2 :6'0"
MH DEPTH # 3 :4'7" 4.58'
PIPE CONDITION:Good
TYPE OF JOINT :SLIP

PIPE TYPE:PVC
PIPE SIZE:8"

FOOTAGE:

53.5 Ft

FAULT OR COMMENTS:

END OF SECTION
TV FOR INSPECTION
OF NEW MAIN.