

(540) 966-3027 TEL  
(540) 966-5906 FAX  
e-mail: [rpierse@rbnet.com](mailto:rpierse@rbnet.com)

## Asbuilts



General Notes:

1. All construction methods and materials shall conform to the latest WWA Design and Construction Standards.
2. The contractor or developer is required to notify the Western Virginia Water Authority in writing of at least three (3) days prior to any construction. Please contact Mark Sink at 537-6450.
3. All work shall be subject to inspection by the Western Virginia Water Authority.
4. Field corrections shall be approved by the Western Virginia Water Authority prior to such construction.
5. The contractor shall maintain a minimum of 18" clearance vertically and 2' minimum horizontally from outside of pipe to outside of pipe at all water, sanitary sewer crossings of any other utilities. Where this cannot be achieved additional measures in accordance with WWA standards shall be enforced.
6. Any existing appurtenances should be adjusted to grade and new frame and covers installed where required.
7. It is the contractor's responsibility to have all existing utilities located and potholed to verify locations. This plan review does not remove the contractor's responsibility to relocate any existing conflicts found during construction.