

DATE STARTED 3-19-85				
DATE COMP. 4-5-85				
FEET MAIN	SIZE	VALVE	VAULT	BOX
606'	8"	2		#2
280'	4"	1		#2
F. H. COMP. 1				
F. H. STUB ONLY				
SERV. INS. BY:				
MAIN INS. BY: C. DAME, U.L.S.				
NO. 3/4" SERV. INS.				
CITY OR CO. CITY				
DEPT. INSP. U.L.S.				

QUANTITY ESTIMATE

520 L.F. 8" D.I. PIPE
 300 L.F. 4" D.I. PIPE
 8X8X4 TEE INTERCONNECTION
 8X8X6 TEE AND HYDRANT ASSY.
 (EA. 2" BLOW OFF ASSEMBLIES.
 1-A "GATE-VALUE w/ BOX TAPPING
 1-8" " " "
 1-8" TAPPING TEE (SLEEVE)

PLUG END OF 4" MAIN AND PROVIDE 2" BLOW OFF AS-BUILT

WOODLEIGH ESTATES

ROANOKE OFFICE OF CITY ENGINEER VIRGINIA

CITY OF ROANOKE
 WATER DEPARTMENT
 8" WATER MAIN EXTENSION ON VALENTINE AVENUE & 4" WATER MAIN EXTENSION ON DAWN LANE

SCALE 1" = 60 FT.
 DATE 2-14-85
 FIELD BK. N/1
 PLAN NO. 8502

APPROVED: Charles M. Huff
 CITY ENGINEER
 APPROVED:

APPROVAL:

Dir. B. Li 2/14/85
 DIRECTOR OF UTILITIES & OPERATIONS

William F. Clark
 DIRECTOR OF PUBLIC WORKS

DISTRIBUTION MAP 507,518

EASTER 138M51882