

Western Virginia Water Authority
UTILITY ACCEPTANCE CERTIFICATE

This is to certify that the following described improvements have been constructed in accordance with the Western Virginia Water Authority Design and Construction Standards. The contractor, developer and surety remain bound by the terms of any applicable agreement(s), and/or (performance, payment, maintenance) guarantee(s).

SUBDIVISION/PROJECT: STRIPER'S LANDING

DEVELOPER: _____

CONTRACTOR: WVWA / CIP2

DESIGN FIRM/ENGINEER: LUMSDEN ASSOCIATES

Project Type: WATER Approximate Lots Served: _____

Plan Number: 19-284 Approval Date: _____ DEQ (If Applicable): _____

Construction Start Date: 8-10-2020

WATER: Pressure Test: PASSED Bacteriological Test: PASSED

Tracer Wire Continuity Test: PASSED (Non-metallic pipe only)

SEWER: Line Pressure Test: _____ MH Test: _____ Camera Inspection: _____

Date of Receipt: As- Builts: 1-22-2021 Easements Recorded: _____

DATE OF SUBSTANTIAL COMPLETION: 1-15-2021

If Punch List is attached, this list of items shall be completed or corrected prior to Final Acceptance. This list may not be all-inclusive, and the failure to include any items on such list does not alter the responsibility of the Contractor to complete all Work in accordance with applicable Agreement(s). Upon Substantial Completion, the Authority may begin use of the accepted water/sewer improvements, however maintenance will remain the responsibility of the Developer/Contractor until Final Acceptance is issued by the Authority.

Punch List Items Complete: 1-15-2021

Maintenance Guarantee Received: 1-15-2021

DATE OF FINAL ACCEPTANCE: 1-22-2021

Water Main (length): (8") 3892' (other) _____ Value: \$ _____

Water Services (number): (2") _____ (other) _____ Value: \$ _____

Water Hydrants (number): 6 Value: \$ _____

Sewer Gravity Main (length): (8") _____ (Other) _____ Value: \$ _____

Sewer Pressure Main (length): () _____ Value: \$ _____

Sewer Manholes (number): _____ Value: \$ _____

Sewer Services (number): (4") _____ (6") _____ Value: \$ _____

Other Utility Improvements Accepted: _____ Value: \$ _____

Inspector: TAFT B.

WVWA Project Manager: JEFF R.