

4. ALL CONSTRUCTION WITHIN THE PUBLIC RIGHT-OF-WAY SHALL BE AS SPECIFIED BY VDOT OR APPLICABLE


5. PRIOR TO CONSTRUCTION, CONTRACTOR IS RESPONSIBLE FOR SECURING ALL REQUIRED PERMITS FROM

6. IN AREAS SUBJECTED TO VEHICULAR TRAFFIC, BEDDING STONE AND FILL SHALL BE PLACED IN 6" LIFTS

FOR DUCTILE SEWER LINE ARE DEPENDENT ON MANUFACTURER'S BEDDING CRITERIA.

AND SHALL BE COMPACTED TO AT LEAST 95% OF MAXIMUM DENSITY AS DETERMINED BY ASTM D 698.

7. ALL SEWER LINE PIPE SHALL BE BEDDED IN COMPACTED GRANULAR MATERIAL. BEDDING REQUIREMENTS



**HURT & PROFFITT, INC. Professional Design Services** www.handp.com

1861 Pratt Dr., Suite 1100 Blacksburg, Va. 24060 540-552-5592 QA / QC

: 03 DEC 18 DESIGNED: BJM DRAWN : BJM CHECKED: RSB

COMMENTS

VDOT AND/OR APPLICABLE LOCALITY.

JACKSON AVENUE / 15TH STREET WATER MAIN REPLACEMENT

WESTERN VIRGINIA WATER AUTHORITY

**WVWA STANDARD DETAILS 3** 

20170430 SHEET