

3 TO 5 MILS IN

24" ABOVE AND AT A MINIMUM OF

BEDDING: FOR WATERLINES, INSTALL BEDDING STONE TO SPRING LINE OF PIPE AT A MINIMUM, OR PER MANUFACTURER'S RECOMMENDATION, FOR SEWER LINES, BEDDING SHALL BE MINIMUM 6" ABOVE PIPE.

WESTERN VIRGINIA REGIONAL - CONSTRUCTION DETAIL

BEDDING AND BACKFILL UNDER PAVEMENT AND IN RIGHT-OF-WAY

SIZE & MATERIAL -

(6" IN ROCK

WIDTH OF TRENCH EXCAVATION -----

AS SHOWN ON PLAN

SEE BEDDING NOTE BELOW

THICKNESS, TO BE

INSTALLED APPROX

MANUFACTURER'S

RECOMMENDATION

FOR SEWER LINES BEDDING

SHALL BE MIN. 6" ABOVE PIPE

ROCK CONDITIONS)

LOCATION OF TRACER WIRE WITH

NON-METALLIC PRESSURE PIPE. TRACER WIRE NOT REQUIRED FOR TYPICAL GRAVITY SANITARY SEWER.

SEE DETAIL G-4 FOR ADDITIONAL

WESTERN VIRGINIA REGIONAL - CONSTRUCTION DETAIL

BEDDING AND BACKFILL OUTSIDE OF PAVED AREAS - DEPTH VARIES

LOCATION OF TRACE WIRE WITH

SEE DETAIL G-4

TRACER WIRE NOT REQUIRED FOR

TYPICAL GRAVITY SANITARY SEWER.




parke

DESIGN GROU

ENGINEERS • SURVEYORS • PLANNERS • LANDSCAPE ARCHITI

816 Boulevard 9 South Harvie Street Richmond, VA 23220 Ph: 540-387-1153 Ph: 540-389-5767 Fax: 540-389-5767 Fax: 804-359-9645 www.parkerdg.com

These documents are the property of Parker Design Group(PDG) and may not be reproduced or used without the express permission of PDG. Any reuse of these documents without authorization of PDG will be at the sole risk of the individual or entity utilizing said documents.



OLOCA DE 11/19/2013 (S) (S) (ONAL ENGLIS) (S) (O

epared for NDRA II, LI

Comprehensive Development Plan Phases I-III

REVISIONS:

Address Comments & Modify Phasi SLR 10-18-20 Address Comme SRB/SLR 2013-11-

Subdivision Site Plan

Phases I-IV

DESIGNED BY: SLR

DRAWN BY: SLR/PJB

CHECKED BY: SLR

17 June 2013

SHEET TITLE:

Water Details

28 OF 32
PROJECT NUMBER:
11-0140-07