


1. FURNISH AND INSTALL NEW MOLDED CASE CIRCUIT BREAKER AS INDICATED. CIRCUIT BREAKER SHALL BE 120VAC, 1-POLE, 1-PHASE BOLT-ON TYPE WITH 10KA SHORT CIRCUIT RATING MATCHING THE EXISTING PANEL.
2. FURNISH AND INSTALL NEW CIRCUIT BREAKER, ALLEN-BRADLEY MODEL 2183FZ-AKB-32TGM, AND BLANK DOOR, ALLEN-BRADLEY MODEL 2100-BK05, IN EXISTING SPARE MCC SPACE IN SECTION 8C.



"file" = C:\197-0\3197-DEC\downloads\DEC\FIC\ Saved by Irmula Save date = 4/2/2015 8:14 AM